

```

1 $ontext
2 *Residential Electricity Consumption Model for Saudi Arabia
3
4 The model can be run for all seasons and regions at once or the user can select
5 a single region or season combination from the options below.
6 $offtext
7 *****
8 Option NLP=PATHNLP;
9 Option limrow=000;
10 Option limcol=000;
11 Option decimals=6;
12 Option savepoint=0;
13 *****
14 Scalars runAllseasons set to 1 to run for all seasons sequentially /1/
15         runSummer set to 1 to run for Summer only /0/
16         runWinter set to 1 to run for Winter only /0/
17         runSprfall set to 1 to run for Spring and fall only /0/
18
19         runAllregions set to 1 to run for all regions sequentially /1/
20         runCent set to 1 to run for COA only /0/
21         runWest set to 1 to run for WOA only /0/
22         runSout set to 1 to run for SOA only /0/
23         runEast set to 1 to run for EOA only /0/;
24 *****
25 Sets
26 Hour hours in a day /hr0*hr24/
27
28 season seasons used in defining parameters /Summ,Wint,
29                                     Spfa spring and fall consolidated/
30 seasonuse(season) seasons used for model run - dynamic set
31
32 Daytype type of day /wday weekdays
33                                     wendhol weekends and holidays/
34
35 *Materials below are listed in order from external surface (top) to interior surface (bottom):
36 *Wall/roof design now based on analysis of Al-Sanea et al. (2005) for Saudi Arabia:
37 m materials /cemplaster1 cement plaster
38                 concrete1 concrete
39                 PolySt polystyrene insulation
40                 concrete2 concrete
41                 cemplaster2 cement plaster/
42 */
43 concrete(m) concrete layers /concrete1
44                                     concrete2/
45
46 cemplaster(m) cement plaster layers /cemplaster1
47                                     cemplaster2/
48 */
49 surface surface /eastern,western,northern,southern,roof/
50 walls(surface) wall surfaces /eastern,western,northern,southern/
51
52 *length=south/north-facing sides; width: east/west-facing sides.
53 dim dimensions /l length,w width,h height/
54
55
56 IHGcomp internal heat gain components /fridge,freezer,dishwasher,washer,dryer,
57                                     waterheater,waterpump,stoven,conelec,
58                                     otherapp,people,lightingincand,
59                                     lightingCFL,lightingLFL,lightingLED,lightingHal/
60
61 Equipment(IHGcomp) IHG components classified as equipment /Fridge refrigerator
62                                     Freezer
63                                     Waterheater
64                                     Waterpump water pump (typically outside th
65
66 e zone i.e. no heat gain contribution)
67
68                                     Dishwasher
69                                     Washer washing machine
70                                     Dryer clothes dryer
71                                     Stoven stove and oven
72                                     Conelec consumer electronics
73                                     Otherapp other appliances/
74
75 withoutpump(equipment) all equipment without water pump /fridge,freezer,waterheater,
76                                     dishwasher,washer,dryer,stoven,conelec,otherapp/
77

```

```

75 Equipdiscretion(equipment) appliances used for discretionary purposes
76                               /Dishwasher,Washer,Dryer,Stoven,Conelec,Otherapp/
77
78 IHGlights(IHGcomp) lighting heat gains /lightingincand,lightingCFL,lightingLFL,
79                               lightingLED,lightingHal/
80
81 bulbtech lighting technologies /incand incandescent lamps
82                               CFL compact fluorescent lamps
83                               LFL linear fluorescent lamps
84                               LED light emitting diodes
85                               Hal halogen lamps/
86
87 fantype /supply,return/
88 ACtype /Window,Split,Central/
89 heattype /sensible,latent/
90
91 x discretized spatial dimension for heat transfer /x1*x6/
92
93 allregions all regions /Cent Riyadh,Sout Abha,West Jeddah,East Qaisumah/
94 r_use(allregions) dynamic set for regions
95
96 coord coordinate elements /lat latitude,long longitude/
97
98 RHsup index over which supply air humidity ratio is cycled /RH1*RH1/
99 Tsup index over which supply air Temperature is cycled /T1*T1/
100 intake index over which quantity of intake AHU air is cycled /intake1*intake1/
101
102 consbrack consumption bracket steps /b1*b8/
103 ;
104 r_use(allregions)=yes;
105 seasonuse(season)=yes;
106 ;
107 alias (surface,surface2);
108 alias (m,m2);
109 alias (hour,hour2);
110 alias (hour,hour3);
111 *****
112 *estimated using data from Saudi Aramco (2001, p. 7)
113 Parameter FracInsulate(allregions) fraction of residences of this type that are insulated
114 /Cent 0.269
115 West 0.320
116 Sout 0.130
117 East 0.281/
118 ;
119 Parameters Numberofresidences(allregions) number of the residential type considered in all regions in»
    units;
120 Numberofresidences('Cent')=(299243+59410+24404)*FracInsulate('Cent');
121 Numberofresidences('West')=(15112+100888+26149)*FracInsulate('West');
122 Numberofresidences('Sout')=(19902+12308+8943+58526)*FracInsulate('Sout');
123 Numberofresidences('East')=(161911+23328+14381)*FracInsulate('East');
124 *Numberofresidnces(allregions)=1;
125
126 Parameter dt time step for FDM discretization in hours;
127 dt=1;
128
129 Scalars
130 sboltzconst Stefan-Boltzmann constant in kJ*K^-4*m^-2*sec^-1 /5.67e-11/
131 Patm atmospheric pressure in kPa /101.325/
132 *Source of enthalpy (McQuiston et al. (2005) page 66)
133 enthalpysatv0C enthalpy of saturated vapor at 0 degrees C in kJ per kgv /2501.3/
134 *The specific heat is treated as a constant as it does not change significantly
135 *in the temperature ranges being considered.
136 Cp vapor specific heat at constant volume for vapor in kJ per kg per K /1.864/
137 R_air ideal gas constant for dry air in kJ per kg per K /0.287058/
138 R_vapor ideal gas constant for water vapor in kJ per kg per K /0.461/
139 *The specific heat is treated as a constant as it does not change significantly in the temperature
140 *ranges being considered.
141 Cp air specific heat for air in kJ per kg per K /1.006/
142 *Sources for fan characteristics: Nilsson (1995, p.3), Santos and Leal (2005, p.113), and
143 *Engdahl and Johansson (2004, p. 213).
144 fanefficiency effective efficiency of the fans taking into account motor and flow efficiencies /1/;
145
146 *fanSFP may already account for efficiency. for right now, we use 1 for fanefficiency.
147 Parameter fanSFP(fantype,allregions) fanSFP for supply and return fans in air conditioning system in »
    kW per cubic meter per second;

```

```

148 fanSFP(fantype,allregions)=0.6;
149 fanSFP(fantype,'Sout')=0.7;
150 fanSFP(fantype,'East')=0.5;
151 fanSFP(fantype,'West')=0.4;
152 fanSFP('return',allregions)=0;
153 *Split and window units have one fan. Central ACs may have two.
154
155 Table Daysinseason(season,daytype) number of days in a season by type
156     wday wendhol
157 Summ  61  32
158 Wint  64  26
159 Spfa 123  59
160 ;
161
162 Parameter Monthsinseason(season) number of months in a season;
163 Monthsinseason('Summ')=3;
164 Monthsinseason('Wint')=3;
165 Monthsinseason('Spfa')=6;
166
167 Parameter ACH(allregions) air changes per hour for the zone;
168 ACH(allregions)=0.70;
169 ACH('West')=0.55;
170 ACH('Sout')=0.90;
171 ACH('East')=0.65;
172
173 *****
174 *****Indoor Properties (often times desired properties)*****
175 *****
176 *Specified based on ASHRAE Standard 55-2010 for indoor thermal comfort.
177 Parameter Tindoor(hour,season,allregions) indoor dry bulb temperature in K;
178 Tindoor(hour,'Summ','Cent')=273.15+25;
179 Tindoor(hour,'Wint','Cent')=273.15+21;
180 Tindoor(hour,'Spfa','Cent')=273.15+22;
181
182 Tindoor(hour,'Summ','East')=273.15+25;
183 Tindoor(hour,'Wint','East')=273.15+21;
184 Tindoor(hour,'Spfa','East')=273.15+22;
185
186 Tindoor(hour,'Summ','Sout')=273.15+22.5;
187 Tindoor(hour,'Wint','Sout')=273.15+20.5;
188 Tindoor(hour,'Spfa','Sout')=273.15+21.5;
189
190 Tindoor(hour,'Summ','West')=273.15+27;
191 Tindoor(hour,'Wint','West')=273.15+26;
192 Tindoor(hour,'Spfa','West')=273.15+26;
193
194 *****
195 *Price-response section, dealing with adjusting indoor zone temperature based on
196 *real-time pricing and household's tolerance for discomfort:
197
198 Scalar discomfottoleranceindex tolerance for discomfort >0 is tolerant- 0 is neutral- and <0 is into
lerant /0/
199 Scalar elecpricethreshold threshold for price increase in the form of ratio of maximum and minimum pr
ices to warrant price response /2/
200 *****
201 Scalar thermostatresolution instrumental resolution of thermostat in degrees K or C /0.1/;
202
203 Parameter elecprice(hour,season,allregions) price of electricity in USD per kwh;
204 elecprice(hour,season,allregions)=0.03;
205 *elecprice(hour,season,allregions)$(ord(hour)>18 and ord(hour)<=21)=0.04;
206 *elecprice(hour,season,allregions)$(ord(hour)>=13 and ord(hour)<=18)=0.06;
207
208 Parameter Tindoormax(hour,season,allregions) maximum indoor temperature allowed by household in Kelvi
n;
209 Tindoormax(hour,season,allregions)=Tindoor(hour,season,allregions)+1;
210
211 Parameter numberofsetpoints(hour,season,allregions) number of set point temperatures between max and »
min temperature;
212 numberofsetpoints(hour,season,allregions)=(Tindoormax(hour,season,allregions)-Tindoor(hour,season,all»
regions))/thermostatresolution+1;
213
214 Parameter dailypricerange(season,allregions) range between maximum and minimum electricity prices for»
a given day in USD per kwh;
215 dailypricerange(season,allregions)=smax(hour,elecprice(hour,season,allregions))-smin(hour,elecprice(h»
our,season,allregions));

```

```

216
217 *The last element of the set j is equal to the value of numberofsetpoints(hour, season, allregions);
218 Set j progression through set-points /j0*j11/;
219
220 Parameter setpointpricerange(j, hour, season, allregions) price range for the thermostat control;
221 setpointpricerange(j, hour, season, allregions)$(ord(j)=1)=smin(hour2, elecprice(hour2, season, allregions)»
);
222
223 Loop(j$(discomforttoleranceindex=0 and ord(j)>1),
224 setpointpricerange(j, hour, season, allregions)=setpointpricerange(j-1, hour, season, allregions)+dailypricerange(season, allregions)/numberofsetpoints(hour, season, allregions)
);
225
226
227 Loop(j$(discomforttoleranceindex<>0 and ord(j)>1),
228 setpointpricerange(j, hour, season, allregions)=setpointpricerange(j-1, hour, season, allregions)
+dailypricerange(season, allregions)*(2**((discomforttoleranceindex*((ord(j)-1)-1))*(1-2**discomforttoleranceindex))/(1-2**((discomforttoleranceindex*numberofsetpoints(hour, season, allregions))))
);
229
230
231 setpointpricerange(j, hour, season, allregions)$(discomforttoleranceindex<0 and setpointpricerange(j, hour, season, allregions)>=smin(hour2, elecprice(hour2, season, allregions))+dailypricerange(season, allregions)/numberofsetpoints(hour, season, allregions)*(card(j)-2))=smax(hour2, elecprice(hour2, season, allregions)));
232
233 Tindoor(hour, season, allregions)$(smax(hour2, elecprice(hour2, season, allregions))>=elecpricethreshold*smin(hour2, elecprice(hour2, season, allregions)))=
thermostatresolution*(smin(j$(ord(j)>1 and (elecprice(hour, season, allregions)<=setpointpricerange(j, hour, season, allregions)+1e-7)), (ord(j)-1)-1))+Tindoor(hour, season, allregions);
234
235 *****
236 display tindoor;
237 *abort'';
238 *Currently the relative humidity is assumed to be maintained at 50%.
239 Parameter relativehumidityin(hour, season, allregions) indoor desired relative humidity;
240 relativehumidityin(hour, season, allregions)=0.50;
241 relativehumidityin(hour, season, 'West')=0.55;
242 relativehumidityin(hour, season, 'Sout')=0.45;
243
244 *For a mixture of perfect gases, the humidity ratio can be written by equation 3-15
245 *on page 52 of McQuiston et al. (2005). The partial pressure of vapor in a saturated
246 *mixture is calculated by:
247 *Saturated vapor pressure(T)=611*10^((7.5*T)/(237.3+T)) where T is in Celsius and pressure in Pa.
248 *We assume the total pressure in the zone is around 1 atm.
249 Parameter humidityratioin(hour, season, allregions) humidity ratio inside zone in kgv per kga;
250 humidityratioin(hour, season, allregions)=relativehumidityin(hour, season, allregions)*0.6219
251 *(0.611*10**((7.5*(Tindoor(hour, season, allregions)-273.15))/(237.3+Tindoor(hour, season, allregions)-273.15)))
/(Patm-(0.611*10**((7.5*(Tindoor(hour, season, allregions)-273.15))/(237.3+Tindoor(hour, season, allregions)-273.15)))));
252
253
254
255 Parameter densityairindoor(hour, season, allregions) density of indoor moist air in kga per cubic meter;
256 densityairindoor(hour, season, allregions)=(1+humidityratioin(hour, season, allregions))/(1+(R_vapor/R_air)*humidityratioin(hour, season, allregions))*Patm/(R_air*Tindoor(hour, season, allregions));
257
258
259 Parameter enthalpyfgindoor(hour, season, allregions) latent heat of vaporization for vapor at indoor temperature in J per kgv;
260 *at Tindoor (from thermodynamics book, p. 760);
261 enthalpyfgindoor(hour, 'Summ', 'Cent')=2442.3;
262 enthalpyfgindoor(hour, 'Wint', 'Cent')=2451.8;
263 enthalpyfgindoor(hour, 'Spfa', 'Cent')=2449.4;
264
265 enthalpyfgindoor(hour, 'Summ', 'East')=2442.3;
266 enthalpyfgindoor(hour, 'Wint', 'East')=2451.8;
267 enthalpyfgindoor(hour, 'Spfa', 'East')=2449.4;
268
269 enthalpyfgindoor(hour, 'Summ', 'Sout')=(2447+2449.4)/2;
270 enthalpyfgindoor(hour, 'Wint', 'Sout')=(2454.1+2451.8)/2;
271 enthalpyfgindoor(hour, 'Spfa', 'Sout')=(2451.8+2449.4)/2;
272
273 enthalpyfgindoor(hour, 'Summ', 'West')=2437.6;
274 enthalpyfgindoor(hour, 'Wint', 'West')=2439.9;
275 enthalpyfgindoor(hour, 'Spfa', 'West')=2439.9;
276
277 *htranscoeffin from page 240.

```

```

278 *4.15e-3 for the ceiling when heating, 1.02e-3 when cooling.
279 *Temperature of the ceiling surface is lower than the indoor air temperature, so
280 *heat flows upward. The opposite is true for the Summer.
281 Parameter htranscoeffin(surface) interior surface convection coefficient in kW*K^-1*m^-2;
282 htranscoeffin(walls)=3.18e-3;
283 htranscoeffin('roof')=4.15e-3;
284 ;
285
286 *****
287 *****Occupancy pattern*****
288 *****
289 Parameter HHsize(allregions) household size per region for the residence type under study
290 /Cent 7.69
291 West 7.40
292 Sout 7.17
293 East 7.81/
294 ;
295 *Defining occupancy schedule as a percentage of total household size for weekdays and weekends:
296 Parameter Occupancy(daytype, hour, allregions) number of occupants throughout the day;
297 Occupancy('wday', hour, allregions)=1*HHsize(allregions);
298 Occupancy('wday', hour, allregions)$ (ord(hour)<=17 and ord(hour)>=9)=0.5*HHsize(allregions);
299 Occupancy('wday', hour, allregions)$ (ord(hour)<=23 and ord(hour)>=21)=0.8*HHsize(allregions);
300
301 Occupancy('wendhol', hour, allregions)=1*HHsize(allregions);
302 Occupancy('wendhol', hour, allregions)$ (ord(hour)<=17 and ord(hour)>=15)=0.9*HHsize(allregions);
303 Occupancy('wendhol', hour, allregions)$ (ord(hour)<=21 and ord(hour)>=18)=0.1*HHsize(allregions);
304 Occupancy('wendhol', hour, allregions)$ (ord(hour)<=23 and ord(hour)>=22)=0.8*HHsize(allregions);
305
306 *****
307 *****Residence Dimensions*****
308 *****
309
310 Parameter occupancydensity(allregions) number of people per square meter of living space;
311 occupancydensity('Cent')=1/67.7387;
312 occupancydensity('West')=1/57.8767;
313 occupancydensity('Sout')=1/51.8308;
314 occupancydensity('East')=1/89.8025;
315
316 Parameter totalfloorarea(allregions) estimated floor area in sq. meters;
317 totalfloorarea(allregions)=HHsize(allregions)/occupancydensity(allregions);
318
319 Parameter numberfloors(allregions) estimated number of floors in the entire thermal envelope for the »
    residence type;
320 numberfloors(allregions)=2.5;
321
322 Parameter Dimension(dim, allregions) spatial dimensions of zone in meters (see diagram);
323 Dimension('l', allregions)=(totalfloorarea(allregions)/numberfloors(allregions))*0.5;
324 Dimension('w', allregions)=Dimension('l', allregions);
325 *Below, assuming 10 feet per floor
326 Dimension('h', allregions)=numberfloors(allregions)*3.048;
327 display dimension, totalfloorarea;
328 *abort'';
329 Parameter zonevolume(allregions) calculates the zone air volume in cubic meters;
330 zonevolume(allregions)=prod(dim, Dimension(dim, allregions));
331 ;
332 Parameter Surfarea(surface, allregions) surface area of walls in meters squared (see diagram);
333 Surfarea('western', allregions)=Dimension('w', allregions)*Dimension('h', allregions);
334 Surfarea('eastern', allregions)=Dimension('w', allregions)*Dimension('h', allregions);
335 Surfarea('northern', allregions)=Dimension('l', allregions)*Dimension('h', allregions);
336 Surfarea('southern', allregions)=Dimension('l', allregions)*Dimension('h', allregions);
337 Surfarea('roof', allregions)=Dimension('l', allregions)*Dimension('w', allregions);
338
339
340
341 *Emissivity, thermal diff, and thermal cond values from Bejan's book (p. 537 and 625)
342 *****
343 *****Walls/Roof Material Properties*****
344 *****
345 Parameter thermdiff(m, surface) thermal diffusivity in sq. m per second;
346 *thermdiff(m, surface)=4.6e-7;
347 *$ontext
348 thermdiff(cemplaster, surface)=5.8e-7;
349 *thermdiff('cemplaster1', 'roof')=1.3e-3/(0.84*2150);
350 thermdiff('PolySt', surface)=0.034e-3/(23*1.28);
351 thermdiff(concrete, surface)=6.6e-7;

```

```

352 *$offtext
353 Parameter thermcond(m,surface) thermal conductivity in kW per m per K;
354 *thermcond(m,surface)=0.72e-3;
355 *$ontext
356 thermcond(cemplaster,surface)=0.79e-3;
357 thermcond(concrete,surface)=1.28e-3;
358 thermcond('PolySt',surface)=0.034e-3;
359 *$offtext
360 *Emissivity and absorptivity only applicable to external material.
361 Parameter emissivity(m,surface) emissivity;
362 emissivity(m,surface)=0.90;
363
364 Parameter solabsorb(m,surface) solar absorptivity;
365 solabsorb(m,surface)=0.50;
366
367
368
369 *****
370 *****Outdoor Conditions*****
371 *****
372 *Average temperatures over entire Summ period using NREL/KACST data for the year 2002.
373 Table Tout(hour,season,allregions) outdoor dry bulb temperature in K
374
375      Summ.West      Wint.West      Spfa.West
376 hr0      303.63      295.57      299.50
377 hr1      302.91      294.93      298.90
378 hr2      302.32      294.48      298.38
379 hr3      301.86      294.15      297.94
380 hr4      301.46      293.88      297.53
381 hr5      301.28      293.57      297.24
382 hr6      301.17      293.38      297.09
383 hr7      302.46      293.36      297.91
384 hr8      304.35      295.06      300.54
385 hr9      306.39      297.65      303.04
386 hr10     308.36      299.33      305.08
387 hr11     309.85      300.66      306.56
388 hr12     310.31      301.54      307.02
389 hr13     310.40      301.94      306.82
390 hr14     310.15      301.93      306.50
391 hr15     310.01      301.60      306.04
392 hr16     309.51      301.05      305.40
393 hr17     309.12      300.23      304.53
394 hr18     308.36      299.06      303.45
395 hr19     307.26      298.06      302.46
396 hr20     306.38      297.30      301.78
397 hr21     305.71      296.65      301.22
398 hr22     305.04      296.19      300.70
399 hr23     304.35      295.75      300.08
400 hr24     303.63      295.57      299.50
401
402      Summ.Cent      Wint.Cent      Spfa.Cent
403 hr0      305.18      286.85      297.05
404 hr1      304.28      286.36      296.29
405 hr2      303.47      285.79      295.65
406 hr3      302.65      285.16      295.00
407 hr4      301.90      284.80      294.37
408 hr5      301.35      284.43      293.88
409 hr6      301.08      284.10      293.62
410 hr7      301.77      283.97      294.30
411 hr8      305.02      285.09      296.53
412 hr9      308.44      287.27      299.26
413 hr10     310.27      288.95      301.24
414 hr11     311.40      290.27      302.57
415 hr12     312.30      291.41      303.59
416 hr13     313.03      292.28      304.37
417 hr14     313.55      292.94      304.91
418 hr15     313.83      293.22      305.06
419 hr16     313.80      293.09      304.93
420 hr17     313.27      292.47      304.18
421 hr18     312.24      291.25      302.94
422 hr19     310.54      290.21      301.62
423 hr20     309.06      289.32      300.46
424 hr21     307.93      288.65      299.50
425 hr22     307.02      287.98      298.72
426 hr23     306.09      287.45      297.85
427 hr24     305.18      286.85      297.05

```

```

427
428 +           Summ.Sout      Wint.Sout      Spfa.Sout
429 hr0         293.50         285.76         289.60
430 hr1         292.86         285.34         289.10
431 hr2         292.35         284.95         288.59
432 hr3         291.99         284.60         288.05
433 hr4         291.45         284.20         287.48
434 hr5         290.78         283.93         287.06
435 hr6         290.66         283.75         286.76
436 hr7         293.37         283.88         289.08
437 hr8         296.77         286.06         292.35
438 hr9         299.07         288.07         294.69
439 hr10        300.65         289.71         296.16
440 hr11        301.70         290.90         297.21
441 hr12        302.25         291.62         297.82
442 hr13        302.19         292.05         298.25
443 hr14        301.60         292.11         298.17
444 hr15        301.07         291.79         297.62
445 hr16        300.14         291.25         296.86
446 hr17        299.07         290.33         295.66
447 hr18        297.95         289.04         294.17
448 hr19        296.65         288.19         293.00
449 hr20        295.91         287.56         292.19
450 hr21        295.40         287.06         291.43
451 hr22        294.65         286.54         290.71
452 hr23        294.12         286.11         290.08
453 hr24        293.50         285.76         289.60
454
455 +           Summ.East      Wint.East      Spfa.East
456 hr0         305.27         284.99         295.77
457 hr1         304.36         284.46         295.10
458 hr2         303.48         284.01         294.56
459 hr3         302.76         283.65         293.97
460 hr4         302.07         283.28         293.42
461 hr5         301.46         282.93         292.98
462 hr6         301.54         282.44         292.98
463 hr7         304.08         282.43         294.48
464 hr8         307.49         284.67         297.05
465 hr9         310.28         287.11         299.56
466 hr10        312.33         289.28         301.59
467 hr11        313.77         290.75         303.22
468 hr12        314.68         291.80         304.30
469 hr13        315.36         292.39         305.02
470 hr14        315.83         293.01         305.43
471 hr15        316.01         293.18         305.54
472 hr16        315.86         292.98         305.10
473 hr17        315.38         292.14         304.20
474 hr18        314.21         290.50         302.58
475 hr19        312.17         289.14         300.88
476 hr20        310.18         287.95         299.53
477 hr21        308.72         287.04         298.32
478 hr22        307.43         286.23         297.29
479 hr23        306.20         285.60         296.45
480 hr24        305.27         284.99         295.77
481
482 ;
483 *Tout(hour,season,r_use)=Tout(hour,season,r_use)-2;
484 ;
485 *Average relative humidity over entire Summ period using NREL/KACST data for the year 2002.
486 Table relativehumidityout(hour,season,allregions) relative humidity
487 *relativehumidityout(hour,season,r_use)=0.8;
488 *$ontext
489           Summ.West      Wint.West      Spfa.West
490 hr0         0.74         0.82         0.82
491 hr1         0.76         0.81         0.83
492 hr2         0.78         0.81         0.84
493 hr3         0.82         0.81         0.85
494 hr4         0.85         0.81         0.85
495 hr5         0.86         0.82         0.86
496 hr6         0.89         0.82         0.87
497 hr7         0.90         0.80         0.85
498 hr8         0.86         0.74         0.78
499 hr9         0.73         0.62         0.66
500 hr10        0.62         0.55         0.55
501 hr11        0.56         0.51         0.50

```

502	hr12	0.55	0.49	0.51
503	hr13	0.54	0.50	0.53
504	hr14	0.54	0.52	0.54
505	hr15	0.54	0.54	0.56
506	hr16	0.56	0.56	0.58
507	hr17	0.56	0.59	0.62
508	hr18	0.58	0.65	0.67
509	hr19	0.62	0.70	0.72
510	hr20	0.66	0.75	0.75
511	hr21	0.69	0.78	0.77
512	hr22	0.70	0.79	0.78
513	hr23	0.72	0.80	0.80
514	hr24	0.74	0.82	0.82
515	*\$offtext			
516				
517	+	Summ.Cent	Wint.Cent	Spfa.Cent
518	hr0	0.20	0.62	0.40
519	hr1	0.21	0.64	0.41
520	hr2	0.22	0.66	0.42
521	hr3	0.23	0.69	0.44
522	hr4	0.24	0.70	0.45
523	hr5	0.25	0.72	0.47
524	hr6	0.26	0.74	0.48
525	hr7	0.27	0.75	0.48
526	hr8	0.25	0.72	0.45
527	hr9	0.20	0.64	0.39
528	hr10	0.17	0.58	0.35
529	hr11	0.16	0.53	0.31
530	hr12	0.15	0.49	0.29
531	hr13	0.14	0.47	0.28
532	hr14	0.14	0.44	0.27
533	hr15	0.13	0.43	0.27
534	hr16	0.13	0.43	0.27
535	hr17	0.13	0.45	0.28
536	hr18	0.14	0.47	0.29
537	hr19	0.15	0.51	0.31
538	hr20	0.16	0.53	0.33
539	hr21	0.17	0.56	0.35
540	hr22	0.18	0.58	0.36
541	hr23	0.19	0.60	0.38
542	hr24	0.20	0.62	0.40
543				
544	+	Summ.Sout	Wint.Sout	Spfa.Sout
545	hr0	0.64	0.88	0.71
546	hr1	0.63	0.88	0.71
547	hr2	0.62	0.89	0.70
548	hr3	0.60	0.90	0.70
549	hr4	0.59	0.91	0.70
550	hr5	0.60	0.92	0.70
551	hr6	0.59	0.92	0.70
552	hr7	0.52	0.92	0.64
553	hr8	0.39	0.84	0.52
554	hr9	0.30	0.74	0.43
555	hr10	0.25	0.68	0.37
556	hr11	0.23	0.63	0.34
557	hr12	0.24	0.63	0.34
558	hr13	0.29	0.62	0.35
559	hr14	0.35	0.65	0.39
560	hr15	0.40	0.68	0.44
561	hr16	0.45	0.72	0.49
562	hr17	0.50	0.78	0.57
563	hr18	0.53	0.87	0.66
564	hr19	0.60	0.91	0.72
565	hr20	0.64	0.92	0.74
566	hr21	0.63	0.90	0.74
567	hr22	0.65	0.89	0.74
568	hr23	0.64	0.88	0.74
569	hr24	0.64	0.88	0.71
570				
571	+	Summ.East	Wint.East	Spfa.East
572	hr0	0.20	0.70	0.44
573	hr1	0.22	0.72	0.46
574	hr2	0.23	0.73	0.47
575	hr3	0.24	0.74	0.49
576	hr4	0.25	0.76	0.50

```

577 hr5      0.26      0.77      0.51
578 hr6      0.26      0.79      0.51
579 hr7      0.24      0.79      0.49
580 hr8      0.21      0.72      0.45
581 hr9      0.18      0.62      0.40
582 hr10     0.16      0.54      0.36
583 hr11     0.15      0.49      0.33
584 hr12     0.14      0.45      0.30
585 hr13     0.13      0.43      0.28
586 hr14     0.13      0.41      0.28
587 hr15     0.12      0.40      0.27
588 hr16     0.12      0.41      0.28
589 hr17     0.12      0.43      0.29
590 hr18     0.13      0.49      0.32
591 hr19     0.14      0.55      0.35
592 hr20     0.15      0.58      0.36
593 hr21     0.17      0.62      0.39
594 hr22     0.18      0.65      0.41
595 hr23     0.19      0.68      0.43
596 hr24     0.20      0.70      0.44
597 ;
598
599 Parameter humidityratioout(hour,season,allregions) humidity ratio outdoor air in kgv per kga;
600 humidityratioout(hour,season,allregions)=relativehumidityout(hour,season,allregions)*0.6219
601 *(0.611*10**((7.5*(Tout(hour,season,allregions)-273.15))/(237.3+Tout(hour,season,allregions)-273.15))»
602 /(Patm-(0.611*10**((7.5*(Tout(hour,season,allregions)-273.15))/(237.3+Tout(hour,season,allregions)-273.15)))));
603
604 ;
605 *SOLAR IRRADIATION CALCULATIONS:
606 $include solarirradmacros.gms
607 scalar timezone Saudi Arabian time zone in degrees W relative to Prime Meridian /315/
608      greflectance ground reflectance (estimated for now) /0.2/;
609
610 *DNI data represent averages for Summ in the regions (Source: KACST/NREL)
611 Table DNI(hour,season,allregions) direct normal irradiance in W per sq. m
612      Summ.West      Wint.West      Spfa.West
613 hr0      0.00      0.00      0.00
614 hr1      0.00      0.00      0.00
615 hr2      0.00      0.00      0.00
616 hr3      0.00      0.00      0.00
617 hr4      0.00      0.00      0.00
618 hr5      0.00      0.00      0.00
619 hr6      0.00      0.00      0.00
620 hr7      108.21      8.62      116.25
621 hr8      220.17      237.29      267.18
622 hr9      284.13      373.35      372.17
623 hr10     322.80      457.99      425.28
624 hr11     366.91      483.59      464.96
625 hr12     371.47      495.44      464.82
626 hr13     385.27      515.21      441.32
627 hr14     358.27      508.24      427.21
628 hr15     337.17      476.44      388.88
629 hr16     288.31      405.86      325.61
630 hr17     214.01      263.59      224.91
631 hr18     98.18      25.45      75.94
632 hr19     0.00      0.00      0.00
633 hr20     0.00      0.00      0.00
634 hr21     0.00      0.00      0.00
635 hr22     0.00      0.00      0.00
636 hr23     0.00      0.00      0.00
637 hr24     0.00      0.00      0.00
638
639 +      Summ.Cent      Wint.Cent      Spfa.Cent
640 hr0      0.00      0.00      0.00
641 hr1      0.00      0.00      0.00
642 hr2      0.00      0.00      0.00
643 hr3      0.00      0.00      0.00
644 hr4      0.00      0.00      0.00
645 hr5      0.00      0.00      0.00
646 hr6      126.18      0.00      69.73
647 hr7      428.50      179.37      345.00
648 hr8      616.34      417.28      537.36
649 hr9      701.90      540.97      630.72

```

650	hr10	758.87	591.76	691.35
651	hr11	790.57	632.42	726.64
652	hr12	787.36	672.32	726.11
653	hr13	769.69	669.87	698.14
654	hr14	731.90	643.80	640.54
655	hr15	660.86	544.11	551.38
656	hr16	549.80	440.87	413.90
657	hr17	343.09	198.41	162.23
658	hr18	82.14	0.00	16.31
659	hr19	0.00	0.00	0.00
660	hr20	0.00	0.00	0.00
661	hr21	0.00	0.00	0.00
662	hr22	0.00	0.00	0.00
663	hr23	0.00	0.00	0.00
664	hr24	0.00	0.00	0.00
665				
666	+	Summ.Sout	Wint.Sout	Spfa.Sout
667	hr0	0.00	0.00	0.00
668	hr1	0.00	0.00	0.00
669	hr2	0.00	0.00	0.00
670	hr3	0.00	0.00	0.00
671	hr4	0.00	0.00	0.00
672	hr5	0.00	0.00	0.00
673	hr6	15.81	0.00	40.81
674	hr7	308.10	162.57	434.72
675	hr8	519.67	481.49	643.23
676	hr9	602.28	636.41	740.30
677	hr10	635.58	660.29	800.84
678	hr11	638.66	691.25	823.31
679	hr12	541.16	679.27	792.25
680	hr13	450.68	665.41	738.68
681	hr14	331.60	614.67	659.61
682	hr15	304.88	565.33	576.88
683	hr16	218.10	460.26	474.79
684	hr17	167.89	281.03	268.43
685	hr18	18.59	0.00	31.64
686	hr19	0.00	0.00	0.00
687	hr20	0.00	0.00	0.00
688	hr21	0.00	0.00	0.00
689	hr22	0.00	0.00	0.00
690	hr23	0.00	0.00	0.00
691	hr24	0.00	0.00	0.00
692				
693	+	Summ.East	Wint.East	Spfa.East
694	hr0	0.00	0.00	0.00
695	hr1	0.00	0.00	0.00
696	hr2	0.00	0.00	0.00
697	hr3	0.00	0.00	0.00
698	hr4	0.00	0.00	0.00
699	hr5	0.00	0.00	0.00
700	hr6	169.94	0.00	56.49
701	hr7	436.09	80.39	233.17
702	hr8	602.67	294.03	370.68
703	hr9	681.89	371.92	461.88
704	hr10	743.99	404.94	502.37
705	hr11	768.10	433.38	533.62
706	hr12	761.54	447.63	537.10
707	hr13	750.60	404.87	507.05
708	hr14	721.65	406.25	462.92
709	hr15	663.35	334.87	408.82
710	hr16	560.48	270.14	295.76
711	hr17	391.47	99.81	122.03
712	hr18	122.94	0.00	27.01
713	hr19	0.00	0.00	0.00
714	hr20	0.00	0.00	0.00
715	hr21	0.00	0.00	0.00
716	hr22	0.00	0.00	0.00
717	hr23	0.00	0.00	0.00
718	hr24	0.00	0.00	0.00
719				
720				

```

721 Parameter tiltangle(surface) tilt angle for surface in degress (normal of surface relative to normal »
    of horizontal);
722 tiltangle(walls)=90;
723 tiltangle('roof')=0;

```

```

724
725 *Source: NREL/KACST(2002) for their measurement sites.
726 Table coordinates(coord,allregions) geographical coordinates in deg W for longitude and deg N for lat»
       itude
727         West   Cent   Sout   East
728 lat      21.68  24.91  18.23  28.32
729 long     320.85 313.59 317.49 313.87
730 ;
731
732 Parameter dayofyear(season) day number during the year;
733 dayofyear('Summ')=213;
734 dayofyear('Wint')=37;
735 dayofyear('Spfa')=121;
736
737 Parameter hourofday(hour) assigning numerical values to hour of day;
738 hourofday(hour)=ord(hour)-1;
739
740
741 Parameter Fsg(surface) view factor from surface to ground;
742 Fsg(surface)=(1-cos(tiltangle(surface)*pi/180))/2;
743
744 Parameter Fssky(surface) view factor from surface to sky;
745 Fssky(surface)=(1+cos(tiltangle(surface)*pi/180))/2;
746
747 Parameter C(season) ratio of diffuse irradiance to DNI (from McQuiston et al. (2005 page 187));
748 C('Summ')=0.134;
749 C('Wint')=0.103;
750 C('Spfa')=0.120;
751
752 Parameter positionofearth(season) position of earth in degrees;
753 Parameter equationoftime(season) Equation of time in minutes;
754 Parameter hourocalsolartime(hour,season,allregions) Local solar time in hours;
755 *Hour angle is angle between the projection of the vector of location-to-center of earth on
756 *the equatorial plane and the associated projection of the line from the center of the sun
757 *to the center of the earth.
758 *By convention, the hour angle is negative in the morning, zero at noon, and positive in the afternoo»
       n.
759 Parameter hourangle(hour,season,allregions) the hour angle in degrees;
760 *sol dec: Angle between the line connecting the origins of the Earth and Sun and the line projection
761 *of that line on the earth's season equitorial plane.
762 Parameter surazimuth(hour,surface,season,allregions) the surface azimuth;
763 *orientation of the aperture plane from the north
764 Parameter soldeclination(season) solar declination angle in degrees;
765 *sol alt: Angle between the sun's season rays and the projection of the rays on a horizontal surface.
766 Parameter solaltitude(hour,season,allregions) solar altitude in degrees;
767 *sol azim: Angle between horizontal projection of the sun's season rays and the horizontal direction
768 *measured from the north (clockwise direction).
769 Parameter solazimuth(hour,season,allregions) solar azimuth in degrees;
770 *solsurfazim: Absolute value of the difference between the solar azimuth (phi) and the surface azimuth»
       h (psi).
771 Parameter solarsurfaceazimuth(hour,surface,season,allregions) solar surface azimuth in degrees;
772 *ang of inc: angle between sun's season rays and the normal of the surface
773 Parameter angleofincidence(hour,surface,season,allregions) the angle of incidence in degrees;
774
775
776 positionofearth(season)=earthpos(dayofyear(season));
777
778 equationoftime(season)=EOT(positionofearth(season));
779
780 hourocalsolartime(hour,season,allregions)=solhr(hourofday(hour),Dayofyear(season),coordinates('long',»
       allregions),timezone);
781
782 hourangle(hour,season,allregions)=hourang(hourocalsolartime(hour,season,allregions));
783
784 *Based on chosen diagram for zone orientation (arbitrary for horizontal surfaces);
785 surazimuth(hour,'eastern',season,allregions)=90;
786 surazimuth(hour,'western',season,allregions)=270;
787 surazimuth(hour,'northern',season,allregions)=0;
788 surazimuth(hour,'southern',season,allregions)=180;
789
790 soldeclination(season)=soldecl(positionofearth(season));
791
792 solaltitude(hour,season,allregions)=solalt(hourangle(hour,season,allregions),soldeclination(season),c»
       oordinates('lat',allregions));
793

```

```

794 solazimuth(hour, season, allregions)=solazim(hourangle(hour, season, allregions), soldeclination(season), c»
    oordinates('lat', allregions), solaltitude(hour, season, allregions));
795 solazimuth(hour, season, allregions)$(hourangle(hour, season, allregions)>0 or hourocal solartime(hour, sea»
    son, allregions)>12)=360-solazimuth(hour, season, allregions);
796
797 solarsurfaceazimuth(hour, surface, season, allregions)=Gammasol(solazimuth(hour, season, allregions), suraz»
    imuth(hour, surface, season, allregions));
798
799 angleofincidence(hour, surface, season, allregions)=Incidence(solaltitude(hour, season, allregions), solars»
    urfaceazimuth(hour, surface, season, allregions), tiltangle(surface));
800
801
802 *The total irradiance is now calculated as a function of DNI.
803 Parameter directirradiance(hour, surface, season, allregions) the direct irradiance in kw per sq. m;
804 directirradiance(hour, 'northern', season, allregions)=DNI(hour, season, allregions)*COS(angleofincidence(»
    hour, 'northern', season, allregions)*pi/180)$(solaltitude(hour, season, allregions)>0 and (solazimuth(hou»
    r, season, allregions)<90 or solazimuth(hour, season, allregions)>270));
805 directirradiance(hour, 'southern', season, allregions)=DNI(hour, season, allregions)*COS(angleofincidence(»
    hour, 'southern', season, allregions)*pi/180)$(solaltitude(hour, season, allregions)>0 and (solazimuth(hou»
    r, season, allregions)>90 and solazimuth(hour, season, allregions)<270));
806 directirradiance(hour, 'eastern', season, allregions)=DNI(hour, season, allregions)*COS(angleofincidence(h»
    our, 'eastern', season, allregions)*pi/180)$(solaltitude(hour, season, allregions)>0 and (solazimuth(hour, »
    season, allregions)>0 and solazimuth(hour, season, allregions)<180));
807 directirradiance(hour, 'western', season, allregions)=DNI(hour, season, allregions)*COS(angleofincidence(h»
    our, 'western', season, allregions)*pi/180)$(solaltitude(hour, season, allregions)>0 and (solazimuth(hour, »
    season, allregions)>180 and solazimuth(hour, season, allregions)<360));
808 directirradiance(hour, 'roof', season, allregions)=DNI(hour, season, allregions)*COS(angleofincidence(hour»
    , 'roof', season, allregions)*pi/180)$(solaltitude(hour, season, allregions)>0);
809
810 directirradiance(hour, surface, season, allregions)=directirradiance(hour, surface, season, allregions)*1e-»
    3;
811
812
813 Parameter diffuseirradiance(hour, surface, season, allregions) the diffuse irradiance in kw per sq. m;
814 diffuseirradiance(hour, surface, season, allregions)=Fssky(surface)*C(season)*DNI(hour, season, allregions»
    )*1e-3;
815
816 Parameter reflectedirradiance(hour, surface, season, allregions) the reflected irradiance in kw per sq. »
    m;
817 reflectedirradiance(hour, surface, season, allregions)=greflectance*Fsg(surface)*(C(season)+sin(solaltit»
    ude(hour, season, allregions)*pi/180))*DNI(hour, season, allregions)*1e-3;
818
819
820 *Total irradiance is the sum of direct, diffuse, and reflected irradiation, depending on tilt angle o»
    f surface.
821 Parameter totalirrad(hour, season, surface, allregions) total solar irradiance on a surface in kw per sq»
    r meter;
822 totalirrad(hour, season, surface, allregions)= directirradiance(hour, surface, season, allregions)
823                                     +diffuseirradiance(hour, surface, season, allregions)
824                                     +reflectedirradiance(hour, surface, season, allregions);
825
826 *totalirrad(hour, season, 'west', allregions)=diffuseirradiance(hour, 'west', season, allregions);
827 *totalirrad(hour, season, 'east', allregions)$(ord(hour)>=17)=diffuseirradiance(hour, 'east', season, allre»
    gions);
828
829 *Currently using historical Weibull averages from Rehman et al. (1994) using their
830 *scale and shaper parameters;
831 Parameter windspeed(hour, season, allregions) wind speed in meters per second at a height of around 10 »
    meters;
832 *Using Riyadh averages for central:
833 windspeed(hour, 'Summ', 'Cent')=3.85*gamma(1+1/1.93);
834 windspeed(hour, 'Wint', 'Cent')=3.92*gamma(1+1/1.92);
835 windspeed(hour, 'Spfa', 'Cent')=3.48*gamma(1+1/1.88);
836 *Using Jeddah averages for west:
837 windspeed(hour, 'Summ', 'West')=3.94*gamma(1+1/2.45);
838 windspeed(hour, 'Wint', 'West')=4.30*gamma(1+1/2.13);
839 windspeed(hour, 'Spfa', 'West')=4.01*gamma(1+1/2.20);
840 *Using Najran averages for south:
841 windspeed(hour, 'Summ', 'Sout')=3.71*gamma(1+1/2.43);
842 windspeed(hour, 'Wint', 'Sout')=2.87*gamma(1+1/2.00);
843 windspeed(hour, 'Spfa', 'Sout')=2.89*gamma(1+1/2.18);
844 *Using Dhahran averages for east:
845 windspeed(hour, 'Summ', 'East')=4.88*gamma(1+1/2.33);
846 windspeed(hour, 'Wint', 'East')=4.92*gamma(1+1/2.47);
847 windspeed(hour, 'Spfa', 'East')=5.04*gamma(1+1/2.28);

```

```

848
849
850 Parameter Tground(hour, season, allregions) ground temperature in K;
851 Tground(hour, season, allregions)=300;
852
853 *Below correlation for the outdoor heat transfer coefficient was established by
854 *Jayamaha et al. (1996) for wind speeds ranging from 0 to 4 meters/sec.
855 Parameter htranscoeffout(hour, season, surface, allregions) exterior surface convection coefficient in k>
W*K^-1*m^-2;
856 htranscoeffout(hour, season, surface, allregions)=(1.444*windspeed(hour, season, allregions)+4.955)*1e-3;
857
858
859 Parameter densityairout(season, hour, allregions) density of moist air in kga per cubic meter;
860 densityairout(season, hour, allregions)=(1+humidityratioout(hour, season, allregions))/(1+(R_vapor/R_air)>
*humidityratioout(hour, season, allregions))*Patm/(R_air*Tout(hour, season, allregions));
861
862 Parameter infilvolflowrate(allregions) infiltration volumetric flow rate in cubic meters per second;
863 infilvolflowrate(allregions)=ACH(allregions)*zonevolume(allregions)/3600;
864
865
866
867 *****
868 *****Lighting*****
869 *****
870 *Source for minimum illumination: Jefferis (2013, p. 360).
871 Scalar illuminatemin minimum illumination in lumens per sq. meter /130/;
872
873 Parameter bulbefficacy(bulbtech) bulb efficacy in lumens per kW
874 /incand 16e3
875 CFL 70e3
876 LFL 92e3
877 LED 80e3
878 Hal 21e3/
879 ;
880 Parameter bulbpowerrating(bulbtech) bulb power ratings in kW per bulb
881 /incand 50e-3
882 CFL 23e-3
883 LFL 26e-3
884 LED 20e-3
885 Hal 40e-3/
886 ;
887 *Based on Anwar's calculations using imports data. Only available at the national level.
888 Parameter bulbmarketshare(bulbtech) bulb fraction market share in the residential sector
889 /incand 0.42
890 CFL 0.095
891 LFL 0.36
892 LED 0.00
893 Hal 0.125/
894 ;
895 Parameter bulbsusedfrac(allregions) fraction of lights used by region;
896 bulbsusedfrac(allregions)=0.40;
897 bulbsusedfrac('Sout')=0.37;
898 bulbsusedfrac('West')=0.35;
899 *Here we can use either the illumination requirement data or directly input number of bulbs:
900 *I assume that 50% of the lights are turned on at any one time:
901 Parameter Lightingschedule(bulbtech, season, daytype, hour, allregions) number of lights throughout the d>
ay;
902 Lightingschedule(bulbtech, season, daytype, hour, allregions)$(solaltitude(hour, season, allregions)<=5 and>
(ord(hour)<=23 and ord(hour)>12))=
903 illuminatemin*bulbmarketshare(bulbtech)*Surfarea('roof', allregions)*numberfloors(allregions)*
904 (1/bulbefficacy(bulbtech))*(1/bulbpowerrating(bulbtech))*bulbsusedfrac(allregions);
905
906 Parameter LightingscheduleOutdoor(bulbtech, season, daytype, hour, allregions) number of lights used outs>
ide ie without heat gain contribution;
907 Lightingscheduleoutdoor('Incand', season, daytype, hour, allregions)$(solaltitude(hour, season, allregions)>
<=3)=2;
908
909 *****
910 *****Equipment and Appliances*****
911 *****
912 Parameter spaceheatingsaturation(allregions) percentage of households with electrical space heating
913 /Cent 0.15
914 Sout 0.30
915 West 0.00
916 East 0.05/

```

```

917 ;
918 *Except for the water pump, equipment power draws below are from Gottwalt et al. (2011).
919 *Using the other equipment's power values, the water pump draw is estimated from
920 *the assumed operation schedule below and the amount of electricity consumed by appliances
921 *as cited by The Brattle Group (2011). The water heater power draw is estimated
922 *the same way, using its electricity consumption value cited by The Brattle Group.
923 *Consumer electronics are estimated the same way as the water heaters, and they include
924 *TVs, laptops, desktops, and DVD/BD players.
925 Parameter equippowerrating(equipment,allregions) equipment operational power loads in kW;
926 *some equipment is assumed to use 50% of its rated power consumption on average:
927 equippowerrating('fridge',allregions)=140e-3;
928 equippowerrating('freezer',allregions)=106e-3;
929 equippowerrating('dishwasher',allregions)=530e-3;
930 equippowerrating('washer',allregions)=600e-3;
931 equippowerrating('dryer',allregions)=1410e-3;
932 equippowerrating('stoven',allregions)=(1840)*1e-3;
933 equippowerrating('conelec',allregions)=519.23e-3;
934 equippowerrating('otherapp',allregions)=500e-3;
935 equippowerrating('waterpump',allregions)=1112.7e-3;
936 equippowerrating('waterheater',allregions)=3214e-3;
937
938 *above values are multiplied by the number of residences per envelope:
939 equippowerrating(equipment,allregions)=1*equippowerrating(equipment,allregions);
940
941 ;
942 *Equipment saturation levels below from Dubai Press Club (2012, p. 159-161) and CDSI (2004-2012)
943 *Also assumes that imports constitute nearly 65% of stock:
944 Parameter equipsaturation(equipment) saturation levels in households for appliances in percent
945 /fridge      0.93
946 freezer      0.46
947 dishwasher   0.045
948 washer       0.635
949 dryer        0.069
950 stoven       1.95
951 conelec      3.711
952 otherapp     1.00
953 waterpump    0.92
954 waterheater  1.59/
955 ;
956
957 Parameter equipmentschedule(equipment,season,daytype,hour) use of equipment throughout the day;
958 *For national analysis, these values represent fraction of households for any given hour
959 *when they are awake (estimated from 7 AM to 10 PM) except for fridge, freezer, and water pump:
960 equipmentschedule(equipment,season,daytype,hour)=0;
961 *$ontext
962 equipmentschedule('fridge',season,daytype,hour)=1;
963 equipmentschedule('freezer',season,daytype,hour)=1;
964 equipmentschedule('waterpump',season,daytype,hour)=1/(card(hour)-1);
965 equipmentschedule('dishwasher',season,daytype,hour)$(ord(hour)>=8 and ord(hour)<=23)=1/(23-8);
966 *I assume the washer and dryer are run every other day (hence the 50% multiplier):
967 equipmentschedule('washer',season,daytype,hour)$(ord(hour)>=8 and ord(hour)<=23)=0.5*1/(23-8);
968 equipmentschedule('dryer',season,daytype,hour)$(ord(hour)>=8 and ord(hour)<=23)=0.5*1/(23-8);
969 equipmentschedule('stoven',season,daytype,hour)$(ord(hour)>=8 and ord(hour)<=23)=1/(23-8);
970 equipmentschedule('conelec',season,'wday',hour)$(ord(hour)>=14 and ord(hour)<=23)=1/(23-14);
971 equipmentschedule('conelec',season,'wendhol',hour)$(ord(hour)>=9 and ord(hour)<=23)=1/(23-9);
972 equipmentschedule('otherapp',season,daytype,hour)$(ord(hour)>=8 and ord(hour)<=23)=1/(23-8);
973 *In the summer, I assume only a fraction of water heaters is used:
974 equipmentschedule('waterheater',season,daytype,hour)$(ord(hour)>=8 and ord(hour)<=23)=0.33*1/(23-8);
975 equipmentschedule('waterheater','wint',daytype,hour)$(ord(hour)>=8 and ord(hour)<=23)=1/(23-8);
976 *$offtext
977 *****
978 $ontext
979 This section deals with a household's price response to price changes throughout
980 the day. It is only activated if the ratio of the maximum and minimum prices observed
981 in a 24-hour-period is 2 or higher. Only discretionary uses are included.
982 $offtext
983 $INCLUDE Appliances_priceresponse.gms
984 display equipmentschedule;
985 *abort'';
986 *****
987 ;
988 *While sensible heat gains are divided into radiative and convective components,
989 *latent heat gains are assumed to instantaneously contribute to cooling load (p. 223, McQuiston et al)
990 Parameter Internalheatgain(hour,season,daytype,IHGcomp,heattype,allregions) internal heat gains in kW»

```

```

;
991 *For equipment, it is assumed that that 50% of the total nameplate input ratings
992 *contribute to heat gain (page 225 of McQuiston et al.):
993 Internalheatgain(hour, season, daytype, equipment, 'sensible', allregions)$(withoutpump(equipment))=
994 0.5*equipsaturation(equipment)*equimentschedule(equipment, season, daytype, hour)*equippowerrating(equi»
pment, allregions);
995
996
997 *From Table 8-2 (p. 222) for seated people doing very light work :
998 *72 W/adult and 45 W/adult for sensible and latent heat types, respectively.
999 Internalheatgain(hour, season, daytype, 'people', 'sensible', allregions)=72e-3*Occupancy(daytype, hour, all»
regions);
1000 Internalheatgain(hour, season, daytype, 'people', 'latent', allregions)=45e-3*Occupancy(daytype, hour, allre»
gions);
1001
1002 Internalheatgain(hour, season, daytype, 'lightingincand', 'sensible', allregions)=bulbpowerrating('incand'»
)*Lightingschedule('incand', season, daytype, hour, allregions);
1003 Internalheatgain(hour, season, daytype, 'lightingCFL', 'sensible', allregions)=bulbpowerrating('CFL')*Ligh»
tingschedule('CFL', season, daytype, hour, allregions);
1004 Internalheatgain(hour, season, daytype, 'lightingLFL', 'sensible', allregions)=bulbpowerrating('LFL')*Ligh»
tingschedule('LFL', season, daytype, hour, allregions);
1005 Internalheatgain(hour, season, daytype, 'lightingLED', 'sensible', allregions)=bulbpowerrating('LED')*Ligh»
tingschedule('LED', season, daytype, hour, allregions);
1006 Internalheatgain(hour, season, daytype, 'lightingHal', 'sensible', allregions)=bulbpowerrating('Hal')*Ligh»
tingschedule('Hal', season, daytype, hour, allregions);
1007
1008 *Fraction values from Table 8-20 (p. 263) and page. 224.
1009 Parameter Fracconv(IHGcomp) fraction of internal heat gains (above) that is convective;
1010 Fracconv(equipment)=0.8;
1011 Fracconv('people')=0.3;
1012 Fracconv('lightingincand')=0.2;
1013 Fracconv('lightingcfl')=0.33;
1014 Fracconv('lightinglfl')=0.33;
1015 Fracconv('lightinghal')=0.2;
1016
1017 Parameter Fracrad(IHGcomp) fraction of internal heat gains (above) that is radiative;
1018 Fracrad(equipment)=0.2;
1019 Fracrad('people')=0.7;
1020 Fracrad('lightingincand')=0.8;
1021 Fracrad('lightingcfl')=0.67;
1022 Fracrad('lightinglfl')=0.67;
1023 Fracrad('lightinghal')=0.8;
1024 ;
1025
1026
1027
1028 *****
1029 *****Windows*****
1030 *****
1031 $ontext
1032 We here define the properties of solar heat gain and conduction through fenestrations.
1033 The current system represented is a 1/4-in. uncoated double glazing system (ID 5b).
1034 We can change properties by selecting other systems from table 7-3 on page 200
1035 (McQuiston et al. (2005)).
1036 $offtext
1037 Scalar diffusesolartransmit from table 7-3 pg 200 /0.75/
1038 *Above transmittance value is for single-glazed windows^^
1039 solarabsorbfloor solar absorptivity of the floor /0.8/
1040 Uglazing overall heat transfer coefficient for windows in kW per sq. m per K (Table 5-7 page 1»
46) /1e-3/
1041 convectivecomponentwindows convective component of heat transfer through windows (page 268) /0»
.37/
1042
1043 Parameter Indoorshadingtransmit(allregions) if no internal shading value is unity;
1044 Indoorshadingtransmit(allregions)=0.5;
1045 Indoorshadingtransmit('West')=0.6;
1046 Indoorshadingtransmit('Sout')=0.4;
1047
1048 Parameter totglazingarea(surface, allregions) total glazing area for each surface in sq. m;
1049 totglazingarea(surface, allregions)=0.15*surfarea(surface, allregions);
1050
1051 *To redefine solid wall material used for conduction calculations by netting out
1052 *windows:
1053 Surfarea(surface, allregions)=Surfarea(surface, allregions)-totglazingarea(surface, allregions);
1054

```

```

1055
1056 Parameter diffuseSHG(hour,surface,season,allregions) transmitted diffuse solar radiation in kw per sq>
    meter;
1057 diffuseSHG(hour,surface,season,allregions)=
1058 Indoorshadingtransmit(allregions)*diffusesolartransmit*diffuseirradiance(hour,surface,season,allregio>
    ns)*totglazingarea(surface,allregions);
1059
1060 *The following is a curve-fit of data on page 200, table 7-3. Estimated using Eviews.
1061 *Assuming single-glazed window:
1062 Parameter directsolartransmit(hour,surface,season,allregions) transmittance of direct solar irradianc>
    e;
1063 directsolartransmit(hour,surface,season,allregions)=-2.12e-4*sqr(angleofincidence(hour,surface,season>
    ,allregions))
1064 +1.1155e-2*angleofincidence(hour,surface,season,allregions)+0.805248;
1065
1066 directsolartransmit(hour,surface,season,allregions)$((angleofincidence(hour,surface,season,allregions>
    )>90 or angleofincidence(hour,surface,season,allregions)<0))=0;
1067
1068
1069 Parameter sunlitarea(surface,allregions) sunlit portion of the fenestration in sq. meters;
1070 sunlitarea(surface,allregions)=totglazingarea(surface,allregions)*0.7;
1071
1072
1073 Parameter directSHG(hour,surface,season,allregions) transmitted direct solar radiation in kw per sq. >
    meter;
1074 directSHG(hour,surface,season,allregions)=
1075 Indoorshadingtransmit(allregions)*directsolartransmit(hour,surface,season,allregions)*directirradianc>
    e(hour,surface,season,allregions)*sunlitarea(surface,allregions);
1076
1077 *****
1078 Parameter COP(season,daytype,hour,allregions) coefficient of performance of HVAC unit;
1079 *Have to set a dummy for now (this is redefined later):
1080 COP(season,daytype,hour,allregions)=1;
1081
1082 *Going through the return fan does not change the humidity ratio:
1083 Parameter humidityratio3(hour,season,allregions) humidity ratio at state 3;
1084 humidityratio3(hour,season,allregions)=humidityratioin(hour,season,allregions);
1085
1086 *Parameters used in conjunction with iterating over many supply air properties:
1087 Parameter Monthlyelectricityconsumed(RHsup,Tsup,intake,season,allregions) in kwh per month;
1088 Parameter Monthlyelectricitycost(RHsup,Tsup,intake,season,allregions) in SAR per month;
1089 Parameter TemperatureinHVACrun(Tsup,season,daytype,hour,allregions) to take into account iteration;
1090 Parameter humidityratioinHVACrun(RHsup,season,daytype,hour,allregions) to take into account iteration>
    ;
1091 Parameter MassintakeAHUrun(intake,season,daytype,hour,allregions) to take into account iteration;
1092 Parameter savemassintakeAHU(season,daytype,hour,allregions) initial iteration point for outside air q>
    uantity;
1093 Parameter savehumidityratioinHVAC(season,daytype,hour,allregions) initial iteration point for supply >
    air humidityratio;
1094 Parameter saveTemperatureinHVAC(season,daytype,hour,allregions) initial iteration point for supply ai>
    r temperature;
1095 Parameter TotalPowerExcel(season,daytype,hour,allregions,consbrack) to format the total power correct>
    ly for Excel use;
1096
1097 Parameter upconsumptionlevel(consbrack) upper consumption levels in each bracket in kwh;
1098 upConsumptionlevel('b1')=2000;
1099 upConsumptionlevel('b2')=4000;
1100 upConsumptionlevel('b3')=6000;
1101 upConsumptionlevel('b4')=7000;
1102 upConsumptionlevel('b5')=8000;
1103 upConsumptionlevel('b6')=9000;
1104 upConsumptionlevel('b7')=10000;
1105 upConsumptionlevel('b8')=+inf;
1106
1107 Parameter electariff(consbrack) electricity price in SAR per kwh corresponding to each bracket;
1108 electariff('b1')=5;
1109 electariff('b2')=10;
1110 electariff('b3')=12;
1111 electariff('b4')=15;
1112 electariff('b5')=20;
1113 electariff('b6')=22;
1114 electariff('b7')=24;
1115 electariff('b8')=26;
1116 electariff(consbrack)=electariff(consbrack)/100;
1117

```

```

1118 Scalar elecfixeditariff fixed charge for meter reading in SAR /15/;
1119 *****
1120 Variables
1121 ctot objective value (total cost)
1122
1123 Heatfluxint(x, season, daytype, hour, surface, allregions) heat flux at internal surface in kw per sq. met>
er
1124 Heatfluxext(x, season, daytype, hour, surface, allregions) heat flux at exterior surface in kw per sq. met>
er
1125 masswaterAHU(season, daytype, hour, allregions) mass flow rate of added or removed water from air in kg >
per sec
1126 Qcooling(season, daytype, hour, allregions) cooling load in kw
1127 Qcoil(season, daytype, hour, allregions) heat transefer rate from or to coil in kw
1128
1129 ;
1130 Positive Variables
1131 Temperature(x, season, daytype, hour, m, surface, allregions) temperature in Kelvin in spatial dimension an>
d time of day
1132 L(m, surface) thickness of materials within walls or roof in meters
1133 dx(m, surface) spatial step for FDM scheme in meters
1134 massinHVAC(season, daytype, hour, allregions) mass flow rate into zone in kg per sec
1135 massoutHVAC(season, daytype, hour, allregions) mass flow rate of return air in kg per second
1136 enthalpyinHVAC(season, daytype, hour, allregions) enthalpy of supply air in kJ per kga
1137 massexhaustAHU(season, daytype, hour, allregions) mass flow rate of air going to atmosphere in kg per se>
c
1138 massintakeAHU(season, daytype, hour, allregions) mass flow rate coming into AHU from atmosphere in kg pe>
r sec
1139 massrecircAHU(season, daytype, hour, allregions) mass flow rate of recirculated air in kg per sec
1140 TotalHVACpower(season, daytype, hour, allregions) total power consumption of HVAC system in kw
1141 humidityratio6(season, daytype, hour, allregions) humidity ratio before coil in kg of vapor per kg of ai>
r
1142 humidityratioinHVAC(season, daytype, hour, allregions) humidity ratio after coil in kg of vapor per kg o>
f air
1143 temperatureinHVAC(season, daytype, hour, allregions) supply air temperature in degrees C
1144 enthalpy7(season, daytype, hour, allregions) enthalpy of air after passing through coil in kJ per kga
1145 enthalpy3(season, daytype, hour, allregions) enthalpy of air after passing through return fan in kJ per >
kga
1146 enthalpy6(season, daytype, hour, allregions) enthalpy of air before passing through return fan kJ per kg>
a
1147 Lightingpower(season, daytype, hour, allregions) power consumption by lighting in kw
1148 Equipmentpower(season, daytype, hour, allregions) power consumption by equipment in kw
1149 Totalpower(season, daytype, hour, allregions) total power consumption in kw
1150
1151 Qcoilminus(season, daytype, hour, allregions)
1152 Qcoilplus(season, daytype, hour, allregions)
1153
1154
1155 Negative Variables
1156 Wfansup(season, daytype, hour, allregions) power required from supply fan in kw
1157 Wfanret(season, daytype, hour, allregions) power required from return fan in kw
1158 ;
1159
1160 ;
1161 Equation
1162 objective objective function to solve NLP
1163
1164 spacestepbal(m, surface) used to define spatial step for FDM discretization for each each layer
1165 Temperatureprofile(x, season, daytype, hour, m, surface, allregions) used to generate temperature profiles >
inside walls
1166 boundarycondition1(x, season, daytype, hour, m, surface, allregions) used to define flux BCs at external su>
rfaces
1167 boundarycondition2(x, season, daytype, hour, m, surface, allregions) used to define flux BCs at internal su>
rfaces
1168 intermediateBC1(season, daytype, hour, m, surface, allregions) used to define temperature BCs at interface>
s
1169 intermediateBC2(season, daytype, hour, m, surface, allregions) used to define derivative BCs at interfaces
1170 Energyextbal(x, season, daytype, hour, m, surface, allregions) used to compute the heat flux at exterior su>
rface
1171 Energyintbal(x, season, daytype, hour, m, surface, allregions) used to compute the heat flux at interior su>
rface
1172 Zoneenergybal1(season, daytype, hour, allregions) energy balance for the zone air used to compute coolin>
g load
1173 Zoneenergybal2(season, daytype, hour, allregions) energy balance for the zone air used to compute coolin>
g load
1174 Zonemassbal(season, daytype, hour, allregions) mass balance for zone air

```

```

1175 AHUmassbal2(season,daytype,hour,allregions) mass balance for return portion of AHU
1176 AHUmassbal3(season,daytype,hour,allregions) mass balance for supply portion of AHU
1177 Supplytempcalc(season,daytype,hour,allregions) used to calculate supply air temperature
1178 *AHUenergybalcoil(season,daytype,hour,allregions) air energy balance using cooling coil as control vo»
lume
1179 *AHUenergybalfansup(season,daytype,hour,allregions) air energy balance using supply fan as control vo»
lume
1180 AHUenergybalmixing(season,daytype,hour,allregions) air energy balance using mixing box as control vol»
ume
1181 AHUvapormassbalmixing(season,daytype,hour,allregions) vapor mass balance using mixing box as control »
volume
1182 AHUvapormassbalcoilfansup(season,daytype,hour,allregions) vapor mass balance using cooling coil and s»
upply fan as control volume
1183 AHUenergybalcoilfansup(season,daytype,hour,allregions) air energy balance using cooling coil and supp»
ly fan as control volume
1184 *AHUrecircreq(season,daytype,hour,allregions) temporary replacement to AHUenergybalmixing
1185 AHUenergybalfanret(season,daytype,hour,allregions) air energy balance using return fan as control vol»
ume
1186 SFPfanretreq(season,daytype,hour,allregions)
1187 SFPfansupreq(season,daytype,hour,allregions)
1188 HVACpowerbal(season,daytype,hour,allregions) to calculate total power consumption for HVAC use
1189 Lightingpowercons(season,daytype,hour,allregions) to calculate lighting power consumption
1190 Equipmentpowercons(season,daytype,hour,allregions) to calculate equipment power consumption
1191 Totpowercons(season,daytype,hour,allregions) to aggregate total power consumption in the household
1192 Qcoildecomp(season,daytype,hour,allregions) used in the linearization of abs(qcoil)
1193 Qcoilprod(season,daytype,hour,allregions) used in the liearization of abs(qcoil)
1194 ;
1195
1196 *Specifying material thicknesses in meters:
1197 L.fx(cemplaster,surface)=0.020;
1198 L.fx('concrete1',surface)=0.130;
1199 L.fx('PolySt',surface)=0.025;
1200 L.fx('concrete2',surface)=0.130;
1201 $ontext
1202 L.fx('cemplaster1','roof')=0.010;
1203 L.fx('concrete1','roof')=0.025;
1204 L.fx('airspace','roof')=0.025;
1205 L.fx('concrete2','roof')=0.100;
1206 L.fx('cemplaster2','roof')=0.020;
1207 $offtext
1208 dx.l(m,surface)=0.1;
1209
1210
1211 enthalpy3.lo(season,daytype,hour,allregions)=(      (Cpair*(Tindoor(hour,season,allregions)-273.15)
1212 +humidityratioin(hour,season,allregions)*(Cpvapor*(Tindoor(hour,season,allregions)-273.15)+enthalpysa»
tv0C)) );
1213 *enthalpy3.up(season,daytype,hour,r_use)=enthalpy3.lo(season,daytype,hour,r_use)+5;
1214
1215 *enthalpy7.lo(season,daytype,hour,r_use)=enthalpyinHVAC.lo(season,daytype,hour,r_use)-0;
1216 *enthalpy7.up(season,daytype,hour,r_use)=enthalpyinHVAC.up(season,daytype,hour,r_use);
1217
1218 *enthalpy6.lo(season,daytype,hour,r_use)=2;
1219 *enthalpy6.up(season,daytype,hour,r_use)=enthalpy7.up(season,daytype,hour,r_use)+5;
1220
1221 $ontext
1222 massinHVAC.up(season,daytype,hour,r_use)=1.8;
1223 massinHVAC.lo(season,daytype,hour,r_use)=0;
1224 massoutHVAC.up(season,daytype,hour,r_use)=massinHVAC.up(season,daytype,hour,r_use)+infilvolflowrate;
1225 massoutHVAC.lo(season,daytype,hour,r_use)=0;
1226 massrecircAHU.up(season,daytype,hour,r_use)=massoutHVAC.up(season,daytype,hour,r_use);
1227 massrecircAHU.lo(season,daytype,hour,r_use)=0;
1228 $offtext
1229
1230 massintakeAHU.fx(season,daytype,hour,allregions)=0;
1231
1232 $offorder
1233 ;
1234 *****
1235 objective.. ctot=e=0;
1236 *sum((seasonuse,daytype,hour,r_use),Totalpower(seasonuse,daytype,hour,r_use));
1237 *****
1238 $ontext
1239 This section deals with the solution of the transient heat equation through a wall/roof
1240 and the associated energy balances that complete the problem formulation. An implicit
1241 backward in time and centered in space finite difference scheme is used to avoid

```

```

1242 instability when misspecifying the time step.
1243 $offtext
1244 spacestepbal(m,surface).. dx(m,surface)-L(m,surface)/(card(x)-1)=e=0;
1245
1246 Temperatureprofile(x,seasonuse,daytype,hour,m,surface,r_use)$(ord(x)>1 and ord(x)<card(x))..
1247 ( Temperature(x,seasonuse,daytype,hour,m,surface,r_use)*sqr(dx(m,surface))
1248 +(thermdiff(m,surface)*dt*3600)*Temperature(x+1,seasonuse,daytype,hour+1,m,surface,r_use)
1249 -(sqr(dx(m,surface))+2*(thermdiff(m,surface)*dt*3600))*Temperature(x,seasonuse,daytype,hour+1,m,sur»
face,r_use)
1250 +(thermdiff(m,surface)*dt*3600)*Temperature(x-1,seasonuse,daytype,hour+1,m,surface,r_use) )$(ord(ho»
ur)<card(hour))
1251 +
1252 ( Temperature(x,seasonuse,daytype,hour,m,surface,r_use)
1253 -Temperature(x,seasonuse,daytype,'hr0',m,surface,r_use) )$(ord(hour)=card(hour))
1254 =e=0;
1255
1256
1257 *Boundary condition on external surfaces:
1258 boundarycondition1(x,seasonuse,daytype,hour,m,surface,r_use)$(ord(x)=1 and ord(m)=1)..
1259 Temperature(x+1,seasonuse,daytype,hour,m,surface,r_use)
1260 -(1+(dx(m,surface))*htranscoeffout(hour,seasonuse,surface,r_use)/thermcond(m,surface))*Temperature(x»
,seasonuse,daytype,hour,m,surface,r_use)
1261 +dx(m,surface)*htranscoeffout(hour,seasonuse,surface,r_use)/thermcond(m,surface)*Tout(hour,seasonuse»
,r_use)
1262 *Solar radiation terms:
1263 +solabsorb(m,surface)*dx(m,surface)/thermcond(m,surface)*totalirrad(hour,seasonuse,surface,r_use)
1264 *Surface radiation terms:
1265 +emissivity(m,surface)*sboltzconst*dx(m,surface)/thermcond(m,surface)*(Fsg(surface)*(Tground(hour,se»
asonuse,r_use)**4-Temperature(x,seasonuse,daytype,hour,m,surface,r_use)**4)
1266 +Fssky(surface)*( Tout(hour,seasonuse,r_use)-6*cos(tiltangle(surface)*»
pi/180/2))**4
1267 -Temperature(x,seasonuse,daytype,hour,m,surface,r_use)**4))=e»
=0;
1268
1269
1270 *Boundary condition on interior surfaces (to account for the difference between external
1271 *and internal surface area differences, we subtract out the effect of thicknesses):
1272 *Also, latent heat is estimated to become an instantaneous component of the cooling load
1273 boundarycondition2(x,seasonuse,daytype,hour,m,surface,r_use)$(ord(x)=card(x) and ord(m)=card(m))..
1274 (1+(dx(m,surface))*htranscoeffin(surface)/thermcond(m,surface))*Temperature(x,seasonuse,daytype,hour,»
m,surface,r_use)
1275 -(dx(m,surface))*htranscoeffin(surface)/thermcond(m,surface)*Tindoor(hour,seasonuse,r_use)
1276 *Radiative component of internal heat gains:
1277 +dx(m,surface)/thermcond(m,surface)*(
1278 sum((IHGcomp),Internalheatgain(hour,seasonuse,daytype,IHGcomp,'sensible',r_use)*Fracrad(IHGcomp))
1279 /sum(surface2,surfarea(surface2,r_use)
1280 -(dimension('w',r_use)*sum(m2,L(m2,'roof'))+dimension('h',r_use)*sum(m2,L(m2,'s»
outhern'))+dimension('h',r_use)*sum(m2,L(m2,'northern'))-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'northern'))»
)-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'southern'))))$(ord(surface2)<=2)
1281 -(dimension('h',r_use)*sum(m2,L(m2,'eastern'))+dimension('h',r_use)*sum(m2,L(m2»
,'western'))+dimension('l',r_use)*sum(m2,L(m2,'roof'))-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'western'))-s»
um(m2,L(m2,'roof'))*sum(m2,L(m2,'eastern'))))$(ord(surface2)=3 or ord(surface2)=4)
1282 -(dimension('l',r_use)*sum(m2,L(m2,'northern'))+dimension('l',r_use)*sum(m2,L(m»
2,'southern'))+dimension('w',r_use)*sum(m2,L(m2,'western'))+dimension('w',r_use)*sum(m2,L(m2,'eastern»
'))-sum(m2,L(m2,'northern'))*sum(m2,L(m2,'western'))-sum(m2,L(m2,'northern'))*sum(m2,L(m2,'eastern'))»
)-sum(m2,L(m2,'southern'))*sum(m2,L(m2,'western'))-sum(m2,L(m2,'southern'))*sum(m2,L(m2,'eastern'))))$»
ord(surface2)=card(surface2)) )
1283 )
1284 *Solar thermal radiation transmitted through windows:
1285 +dx(m,surface)/thermcond(m,surface)*( (diffuseSHG(hour,surface,seasonuse,r_use)
1286 +(1-solarabsorbfloor)*directSHG(hour,surface,seasonuse,r_use))/su»
m(surface2,surfarea(surface2,r_use)
1287 -(dimension('w',r_use)*sum(m2,L(m2,'roof'))+dimension('h',r_use)*sum(m2,L(m2,'s»
outhern'))+dimension('h',r_use)*sum(m2,L(m2,'northern'))-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'northern'))»
)-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'southern'))))$(ord(surface2)<=2)
1288 -(dimension('h',r_use)*sum(m2,L(m2,'eastern'))+dimension('h',r_use)*sum(m2,L(m2»
,'western'))+dimension('l',r_use)*sum(m2,L(m2,'roof'))-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'western'))-s»
um(m2,L(m2,'roof'))*sum(m2,L(m2,'eastern'))))$(ord(surface2)=3 or ord(surface2)=4)
1289 -(dimension('l',r_use)*sum(m2,L(m2,'northern'))+dimension('l',r_use)*sum(m2,L(m»
2,'southern'))+dimension('w',r_use)*sum(m2,L(m2,'western'))+dimension('w',r_use)*sum(m2,L(m2,'eastern»
'))-sum(m2,L(m2,'northern'))*sum(m2,L(m2,'western'))-sum(m2,L(m2,'northern'))*sum(m2,L(m2,'eastern'))»
)-sum(m2,L(m2,'southern'))*sum(m2,L(m2,'western'))-sum(m2,L(m2,'southern'))*sum(m2,L(m2,'eastern'))))$»
ord(surface2)=card(surface2)) )
1290 )
1291 -Temperature(x-1,seasonuse,daytype,hour,m,surface,r_use)=e=0;

```

```

1292
1293
1294 *currently assuming perfect interfaces (look into capture resistances?)
1295 intermediateBC1(seasonuse, daytype, hour, m, surface, r_use)$(ord(m)<card(m))..
1296 sum(x$(ord(x)=card(x)), Temperature(x, seasonuse, daytype, hour, m, surface, r_use))
1297 -sum(x$(ord(x)=1), Temperature(x, seasonuse, daytype, hour, m+1, surface, r_use))=e=0;
1298
1299
1300
1301 intermediateBC2(seasonuse, daytype, hour, m, surface, r_use)$(ord(m)<card(m))..
1302 thermcond(m, surface)/dx(m, surface)*( sum(x$(ord(x)=card(x)), Temperature(x, seasonuse, daytype, hour, m, s»
    urface, r_use))
1303 -sum(x$(ord(x)=card(x)-1), Temperature(x, seasonuse, daytype, hour, m, surface»
    , r_use)) )
1304 -thermcond(m+1, surface)/dx(m+1, surface)*( sum(x$(ord(x)=2), Temperature(x, seasonuse, daytype, hour, m+1»
    , surface, r_use))
1305 -sum(x$(ord(x)=1), Temperature(x, seasonuse, daytype, hour, m+1, surface»
    , r_use)) )=e=0;
1306
1307 *****
1308 *To calculate the conduction heat flux on external and interior surfaces:
1309 Energyextbal(x, seasonuse, daytype, hour, m, surface, r_use)$(ord(x)=1 and ord(m)=1)..
1310 Heatfluxext(x, seasonuse, daytype, hour, surface, r_use)
1311 -htranscoeffout(hour, seasonuse, surface, r_use)*(Tout(hour, seasonuse, r_use)-Temperature(x, seasonuse, da»
    ytype, hour, m, surface, r_use))
1312 -solabsorb(m, surface)*totalirrad(hour, seasonuse, surface, r_use)
1313 -emissivity(m, surface)*sboltzconst*(Fsg(surface)*(Tground(hour, seasonuse, r_use)**4-Temperature(x, sea»
    sonuse, daytype, hour, m, surface, r_use)**4)
1314 +Fssky(surface)*( (Tout(hour, seasonuse, r_use)-6*cos(tiltangle(surface)*»
    pi/180/2))**4
1315 -Temperature(x, seasonuse, daytype, hour, m, surface, r_use)**4)=e»
    =0;
1316
1317
1318
1319 Energyintbal(x, seasonuse, daytype, hour, m, surface, r_use)$(ord(x)=card(x) and ord(m)=card(m))..
1320 Heatfluxint(x, seasonuse, daytype, hour, surface, r_use)
1321 -htranscoeffin(surface)*(Temperature(x, seasonuse, daytype, hour, m, surface, r_use)-Tindoor(hour, seasonus»
    e, r_use))
1322 -sum((IHGcomp), Internalheatgain(hour, seasonuse, daytype, IHGcomp, 'sensible', r_use)*Fracrad(IHGcomp))
1323 /sum(surface2, surfarea(surface2, r_use)
1324 -(dimension('w', r_use)*sum(m2, L(m2, 'roof'))+dimension('h', r_use)*sum(m2, L(m2, 's»
    outhern'))+dimension('h', r_use)*sum(m2, L(m2, 'northern'))-sum(m2, L(m2, 'roof'))*sum(m2, L(m2, 'northern'))»
    )-sum(m2, L(m2, 'roof'))*sum(m2, L(m2, 'southern')))*(ord(surface2)<=2)
1325 -(dimension('h', r_use)*sum(m2, L(m2, 'eastern'))+dimension('h', r_use)*sum(m2, L(m2»
    , 'western'))+dimension('l', r_use)*sum(m2, L(m2, 'roof'))-sum(m2, L(m2, 'roof'))*sum(m2, L(m2, 'western'))-s»
    um(m2, L(m2, 'roof'))*sum(m2, L(m2, 'eastern')))*(ord(surface2)=3 or ord(surface2)=4)
1326 -(dimension('l', r_use)*sum(m2, L(m2, 'northern'))+dimension('l', r_use)*sum(m2, L(m»
    2, 'southern'))+dimension('w', r_use)*sum(m2, L(m2, 'western'))+dimension('w', r_use)*sum(m2, L(m2, 'eastern»
    '))-sum(m2, L(m2, 'northern'))*sum(m2, L(m2, 'western'))-sum(m2, L(m2, 'northern'))*sum(m2, L(m2, 'eastern'))»
    -sum(m2, L(m2, 'southern'))*sum(m2, L(m2, 'western'))-sum(m2, L(m2, 'southern'))*sum(m2, L(m2, 'eastern'))»
    ord(surface2)=card(surface2)))
1327 -(diffuseSHG(hour, surface, seasonuse, r_use)+(1-solarabsorbfloor)*directSHG(hour, surface, seasonuse, r_u»
    se))
1328 /sum(surface2, surfarea(surface2, r_use)
1329 -(dimension('w', r_use)*sum(m2, L(m2, 'roof'))+dimension('h', r_use)*sum(m2, L(m2, 's»
    outhern'))+dimension('h', r_use)*sum(m2, L(m2, 'northern'))-sum(m2, L(m2, 'roof'))*sum(m2, L(m2, 'northern'))»
    )-sum(m2, L(m2, 'roof'))*sum(m2, L(m2, 'southern')))*(ord(surface2)<=2)
1330 -(dimension('h', r_use)*sum(m2, L(m2, 'eastern'))+dimension('h', r_use)*sum(m2, L(m2»
    , 'western'))+dimension('l', r_use)*sum(m2, L(m2, 'roof'))-sum(m2, L(m2, 'roof'))*sum(m2, L(m2, 'western'))-s»
    um(m2, L(m2, 'roof'))*sum(m2, L(m2, 'eastern')))*(ord(surface2)=3 or ord(surface2)=4)
1331 -(dimension('l', r_use)*sum(m2, L(m2, 'northern'))+dimension('l', r_use)*sum(m2, L(m»
    2, 'southern'))+dimension('w', r_use)*sum(m2, L(m2, 'western'))+dimension('w', r_use)*sum(m2, L(m2, 'eastern»
    '))-sum(m2, L(m2, 'northern'))*sum(m2, L(m2, 'western'))-sum(m2, L(m2, 'northern'))*sum(m2, L(m2, 'eastern'))»
    -sum(m2, L(m2, 'southern'))*sum(m2, L(m2, 'western'))-sum(m2, L(m2, 'southern'))*sum(m2, L(m2, 'eastern'))»
    ord(surface2)=card(surface2)))=e=0;
1332
1333 *****
1334 $ontext
1335 Energy balance for the zone air (calculation the cooling load):
1336 Qcooling<0 means heat transfer out of system (cooling)
1337 Qcooling>0 means heat transfer into system (heating)
1338 $offtext
1339
1340 *Applying first law using zone as the control volume:

```

```

1341 Zoneenergybal1(seasonuse,daytype,hour,r_use)..
1342 Qcooling(seasonuse,daytype,hour,r_use)
1343 *Infiltration component (sensible and latent, respectively, all convective)
1344 +infilvolflowrate(r_use)*densityairout(seasonuse,hour,r_use)*Cpair*(Tout(hour,seasonuse,r_use)-Tindo»
or(hour,seasonuse,r_use))
1345 +infilvolflowrate(r_use)*densityairout(seasonuse,hour,r_use)*(humidityratioout(hour,seasonuse,r_use)»
-humidityratioin(hour,seasonuse,r_use))*enthalpyfgindoor(hour,seasonuse,r_use)
1346 *Convective internal sensible and latent heat gain components
1347 +sum((IHGcomp),Internalheatgain(hour,seasonuse,daytype,IHGcomp,'sensible',r_use)*Fracconv(IHGcomp))
1348 +sum((IHGcomp),Internalheatgain(hour,seasonuse,daytype,IHGcomp,'latent',r_use))
1349 *Heat transferred from walls and roof (convection)
1350 *(to account for the difference between external
1351 *and internal surface area differences, we subtract out the effect of thicknesses)
1352 +sum((surface,m,x)$ (ord(m)=card(m) and ord(x)=card(x)),
1353 (surfarea(surface,r_use)-(dimension('w',r_use)*sum(m2,L(m2,'roof'))+dimension('h',r_use)*sum(m2,L»
(m2,'southern'))+dimension('h',r_use)*sum(m2,L(m2,'northern'))-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'nort»
hern'))-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'southern'))))$(ord(surface)<=2)
1354 -(dimension('h',r_use)*sum(m2,L(m2,'eastern'))+dimension('h',r_use)*sum(m»
2,L(m2,'western'))+dimension('l',r_use)*sum(m2,L(m2,'roof'))-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'wester»
n'))-sum(m2,L(m2,'roof'))*sum(m2,L(m2,'eastern'))))$(ord(surface)=3 or ord(surface)=4)
1355 -(dimension('l',r_use)*sum(m2,L(m2,'northern'))+dimension('l',r_use)*sum(»
m2,L(m2,'southern'))+dimension('w',r_use)*sum(m2,L(m2,'western'))+dimension('w',r_use)*sum(m2,L(m2,'e»
astern'))-sum(m2,L(m2,'northern'))*sum(m2,L(m2,'western'))-sum(m2,L(m2,'northern'))*sum(m2,L(m2,'east»
ern'))-sum(m2,L(m2,'southern'))*sum(m2,L(m2,'western'))-sum(m2,L(m2,'southern'))*sum(m2,L(m2,'eastern»
'))))$(ord(surface)=card(surface))*htranscoeffin(surface)*(Temperature(x,seasonuse,daytype,hour,m,sur»
face,r_use)-Tindoor(hour,seasonuse,r_use)))
1356 *Heat transferred through windows (convective component); used Equations 7-33 8-66 of McQuiston et al»
. (2005)
1357 +sum(surface,Uglazing*(Tout(hour,seasonuse,r_use)-Tindoor(hour,seasonuse,r_use))*totglazingarea(surf»
ace,r_use)*convectivecomponentwindows)
1358 =e=0;
1359
1360
1361
1362 Zoneenergybal2(seasonuse,daytype,hour,r_use)..
1363 Qcooling(seasonuse,daytype,hour,r_use)
1364 +massoutHVAC(seasonuse,daytype,hour,r_use)*(Cpair*(Tindoor(hour,seasonuse,r_use)-273.15)
1365 +humidityratioin(hour,seasonuse,r_use)*(Cpvapor*(Tindoor(hour,seasonus»
e,r_use)-273.15)+enthalpysatv0C))
1366 -massinHVAC(seasonuse,daytype,hour,r_use)*enthalpyinHVAC(seasonuse,daytype,hour,r_use)=e=0;
1367
1368
1369
1370 *****Mass Balances*****
1371 *Mass balance for the zone air, accounting for infiltration:
1372 Zonemassbal(seasonuse,daytype,hour,r_use)..
1373 * infilvolflowrate*densityairout(seasonuse,hour,r_use)
1374 +massinHVAC(seasonuse,daytype,hour,r_use)
1375 -massoutHVAC(seasonuse,daytype,hour,r_use)=e=0;
1376
1377
1378 *To calculate supply air temperature:
1379 Supplytempcalc(seasonuse,daytype,hour,r_use)..
1380 temperatureinHVAC(seasonuse,daytype,hour,r_use)*(cpair+cpvapor*humidityratioinHVAC(seasonuse,daytyp»
e,hour,r_use))
1381 -enthalpyinHVAC(seasonuse,daytype,hour,r_use)
1382 +humidityratioinHVAC(seasonuse,daytype,hour,r_use)*enthalpysatv0C=e=0;
1383
1384
1385 *Air mass balance for return portion of AHU:
1386 AHUmassbal2(seasonuse,daytype,hour,r_use).. massoutHVAC(seasonuse,daytype,hour,r_use)
1387 -massexhaustAHU(seasonuse,daytype,hour,r_use)
1388 -massrecircAHU(seasonuse,daytype,hour,r_use)=e=0;
1389
1390
1391 *Air mass balance for supply portion of AHU:
1392 AHUmassbal3(seasonuse,daytype,hour,r_use).. -massinHVAC(seasonuse,daytype,hour,r_use)
1393 +massintakeAHU(seasonuse,daytype,hour,r_use)
1394 +massrecircAHU(seasonuse,daytype,hour,r_use)=e=0;
1395
1396
1397 *Vapor mass balacne for mixing box:
1398 AHUVapormassbalmixing(seasonuse,daytype,hour,r_use)..
1399 massintakeAHU(seasonuse,daytype,hour,r_use)*humidityratioout(hour,seasonuse,r_use)
1400 +massrecircAHU(seasonuse,daytype,hour,r_use)*humidityratio3(hour,seasonuse,r_use)

```

```

1401 -massinHVAC(seasonuse,daytype,hour,r_use)*humidityratio6(seasonuse,daytype,hour,r_use)=e=0;
1402
1403 *Vapor mass balacne for coil/supply fan control volume. Positive if added, negative if removed.
1404 AHUVapormassbalcoilfansup(seasonuse,daytype,hour,r_use)..
1405   masswaterAHU(seasonuse,daytype,hour,r_use)
1406 +massinHVAC(seasonuse,daytype,hour,r_use)*humidityratio6(seasonuse,daytype,hour,r_use)
1407 -massinHVAC(seasonuse,daytype,hour,r_use)*humidityratioinHVAC(seasonuse,daytype,hour,r_use)=e=0;
1408
1409
1410 *Using a control volume that encompasses both the coil and the supply fan:
1411 AHUenergybalcoilfansup(seasonuse,daytype,hour,r_use)..
1412   Qcoil(seasonuse,daytype,hour,r_use)
1413 -Wfansup(seasonuse,daytype,hour,r_use)
1414 -massinHVAC(seasonuse,daytype,hour,r_use)*enthalpyinHVAC(seasonuse,daytype,hour,r_use)
1415 +massinHVAC(seasonuse,daytype,hour,r_use)*enthalpy6(seasonuse,daytype,hour,r_use)=e=0;
1416
1417
1418 *$ontext
1419 *Using mixing box as control volume:
1420 AHUenergybalmixing(seasonuse,daytype,hour,r_use).. massrecircAHU(seasonuse,daytype,hour,r_use)*enthal»
1421 py3(seasonuse,daytype,hour,r_use)
1422 +massintakeAHU(seasonuse,daytype,hour,r_use)*(Cpair*(Tout(hour,seasonuse,r_use)-273.15)
1423 +humidityratioout(hour,seasonuse,r_use)*(Cpvapor*(Tout(hour,seasonuse,»
1424 r_use)-273.15)+enthalpysatv0C))
1425 -massinHVAC(seasonuse,daytype,hour,r_use)*enthalpy6(seasonuse,daytype,hour,r_use)=e=0;
1426 *$offtext
1427 *As zero mass intake from outside is presently enforced, the following equation
1428 *is a simplification of the above AHUenergybalmixing constraint, which is commented out.
1429 *AHUrecircreq(seasonuse,daytype,hour,r_use).. enthalpy3(seasonuse,daytype,hour,r_use)
1430 * -enthalpy6(seasonuse,daytype,hour,r_use)=e=0;
1431
1432
1433 *Using area around return fan as control volume:
1434 AHUenergybalfanret(seasonuse,daytype,hour,r_use).. Wfanret(seasonuse,daytype,hour,r_use)
1435 -massoutHVAC(seasonuse,daytype,hour,r_use)*(Cpair*(Tindoor(hour,seasonuse,r_use)-273.15)
1436 +humidityratioin(hour,seasonuse,r_use)*(Cpvapor*(Tindoor(hour,seasonus»
1437 e,r_use)-273.15)+enthalpysatv0C))
1438 +massoutHVAC(seasonuse,daytype,hour,r_use)*enthalpy3(seasonuse,daytype,hour,r_use)=e=0;
1439
1440
1441 *by convention, work down on the system (air in this case) is negative:
1442 SFPfanretreq(seasonuse,daytype,hour,r_use).. -Wfanret(seasonuse,daytype,hour,r_use)
1443 -fanSFP('return',r_use)*massoutHVAC(seasonuse,daytype,hour,r_use)/densityairindoor(hour,seasonuse,r_»
1444 use)=e=0;
1445
1446 *Assuming the air density here is equal to 1.23 kg/cubic meter.
1447 SFPfansupreq(seasonuse,daytype,hour,r_use).. -Wfansup(seasonuse,daytype,hour,r_use)
1448 -fanSFP('supply',r_use)*massinHVAC(seasonuse,daytype,hour,r_use)/1.265=e=0;
1449
1450
1451 *Summing up total electric power used to meet cooling load:
1452 HVACpowerbal(seasonuse,daytype,hour,r_use).. TotalHVACpower(seasonuse,daytype,hour,r_use)
1453 -(Qcoilplus(seasonuse,daytype,hour,r_use)+Qcoilminus(seasonuse,daytype,hour,r_use))/COP(seasonuse,da»
1454 ytype,hour,r_use)
1455 +(Wfansup(seasonuse,daytype,hour,r_use)+Wfanret(seasonuse,daytype,hour,r_use))/faneficiency=e=0;
1456
1457 *To calculate direct power consumption by equipment (still need to develop);
1458 Equipmentpowercons(seasonuse,daytype,hour,r_use).. Equipmentpower(seasonuse,daytype,hour,r_use)
1459 -sum(equipment,equipsaturation(equipment)*equipmentschedule(equipment,seasonuse,daytype,hour)*equipp»
1460 owerrating(equipment,r_use))=e=0;
1461
1462 *To calculate direct power consumption by lights (still need to develop):
1463 Lightingpowercons(seasonuse,daytype,hour,r_use).. Lightingpower(seasonuse,daytype,hour,r_use)
1464 -sum(bulbtech,bulbpowerrating(bulbtech)*lightingschedule(bulbtech,seasonuse,daytype,hour,r_use))
1465 -sum(bulbtech,bulbpowerrating(bulbtech)*lightingscheduleOutdoor(bulbtech,seasonuse,daytype,hour,r_us»
1466 e))=e=0;
1467
1468 *Summing total power consumption seasonuseally:

```

```

1469 Totpowercons(seasonuse,daytype,hour,r_use).. Totalpower(seasonuse,daytype,hour,r_use)
1470 -TotalHVACpower(seasonuse,daytype,hour,r_use)
1471 -Lightingpower(seasonuse,daytype,hour,r_use)
1472 -Equipmentpower(seasonuse,daytype,hour,r_use)=e=0;
1473
1474 $ontext
1475 *Old constraints that used separate control volumes for supply fan and coil:
1476
1477 *Using area around coil as the control volume:
1478 AHUenergybalcoil(seasonuse,daytype,hour,r_use).. Qcoil(seasonuse,daytype,hour,r_use)
1479 -massinHVAC(seasonuse,daytype,hour,r_use)*enthalpy7(seasonuse,daytype,hour,r_use)
1480 +massinHVAC(seasonuse,daytype,hour,r_use)*enthalpy6(seasonuse,daytype,hour,r_use)=e=0;
1481
1482
1483 *Using area around supply fan as control volume:
1484 AHUenergybalfansup(seasonuse,daytype,hour,r_use).. Wfansup(seasonuse,daytype,hour,r_use)
1485 -massinHVAC(seasonuse,daytype,hour,r_use)*enthalpy7(seasonuse,daytype,hour,r_use)
1486 +massinHVAC(seasonuse,daytype,hour,r_use)*enthalpyinHVAC(seasonuse,daytype,hour,r_use)=e=0;
1487 $offtext
1488
1489 *The following two equation are used to represent the absolute value function
1490 *as a differentiable formulation:
1491 Qcoildecomp(seasonuse,daytype,hour,r_use).. Qcoil(seasonuse,daytype,hour,r_use)
1492 +Qcoilminus(seasonuse,daytype,hour,r_use)
1493 -Qcoilplus(seasonuse,daytype,hour,r_use)=e=0;
1494
1495 Qcoilprod(seasonuse,daytype,hour,r_use)..
1496 Qcoilminus(seasonuse,daytype,hour,r_use)*Qcoilplus(seasonuse,daytype,hour,r_use)=e=0;
1497 ;
1498 *****
1499 Model Residential /objective,spacestepbal,temperatureprofile,boundarycondition1,
1500 boundarycondition2,intermediateBC1,intermediateBC2,Energyextbal,Energyintbal,
1501 Zoneenergybal1,zoneenergybal2,zonemassbal,AHUmassbal2,AHUmassbal3,Supplytempcalc,
1502 AHUenergybalmixing,AHUVapormassbalmixing,AHUVapormassbalcoilfansup,AHUenergybalcoilfansup,
1503 AHUenergybalfanret,SFPfanretreq,SFPfansupreq,HVACpowerbal,Lightingpowercons,
1504 Equipmentpowercons,Totpowercons,Qcoildecomp,Qcoilprod/;
1505
1506 Model Qsystemcheck /objective,spacestepbal,temperatureprofile,boundarycondition1,
1507 boundarycondition2,intermediateBC1,intermediateBC2,Energyextbal,Energyintbal,
1508 Zoneenergybal1/;
1509 *Residential.optfile=1;
1510
1511 *8 GB of memory:
1512 Residential.workspace=8192;
1513 Qsystemcheck.workspace=8192;
1514 *Use all available CPU cores:
1515 Residential.threads=0;
1516 Qsystemcheck.threads=0;
1517 *Scaling to improve performance:
1518 Residential.scaleopt=1;
1519 Qsystemcheck.scaleopt=1;
1520 *SolveLink set to 5 to use RAM exclusively:
1521 *Residential.solveLink=5;
1522 *Qsystemcheck.solveLink=5;
1523
1524 $ontext
1525 AHUenergybalcoil.scale(seasonuse,daytype,hour,r_use)=1e-1;
1526 Qcoil.scale(seasonuse,daytype,hour,r_use)=1e1;
1527 HVACpowerbal.scale(seasonuse,daytype,hour,r_use)=1e-2;
1528 $offtext
1529
1530 r_use(allregions)=no;
1531 r_use('Cent')$((runCent=1 and runAllregions<>1) or runAllregions=1)=yes;
1532 r_use('West')$((runWest=1 and runAllregions<>1)=yes;
1533 r_use('Sout')$((runSout=1 and runAllregions<>1)=yes;
1534 r_use('East')$((runEast=1 and runAllregions<>1)=yes;
1535
1536 Loop(Allregions$((r_use(allregions) and runallregions<>1) or runallregions=1),
1537
1538 seasonuse(season)=no;
1539 seasonuse('Summ')$((runSummer=1 and runAllseasons<>1) or runAllseasons=1)=yes;
1540 seasonuse('Wint')$((runWinter=1 and runAllseasons<>1)=yes;
1541 seasonuse('Spfa')$((runSprfall=1 and runAllseasons<>1)=yes;
1542
1543 Loop(season$((seasonuse(season) and runallseasons<>1) or runallseasons=1),

```

```

1544
1545 *Different scaling requirements by seasons:
1546 If(ord(season)=1,
1547 Temperature.scale(x, season, daytype, hour, m, surface, allregions)=1e2;
1548 Temperatureprofile.scale(x, season, daytype, hour, m, surface, allregions)=1e-2;
1549 intermediateBC2.scale(season, daytype, hour, m, surface, allregions)=1e-2;
1550 AHUenergybalfanret.scale(season, daytype, hour, allregions)=1e1;
1551 AHUenergybalcoilfansup.scale(season, daytype, hour, allregions)=1e2;
1552 AHUenergybalmixing.scale(season, daytype, hour, allregions)=1e3;
1553 AHUvapormassbalmixing.scale(season, daytype, hour, allregions)=1e1;
1554 AHUvapormassbalmixing.scale(season, daytype, hour, 'Sout')=1e1;
1555 );
1556
1557 If(ord(season)=2,
1558 Temperature.scale(x, seasonuse, daytype, hour, m, surface, allregions)=1e2;
1559 Temperatureprofile.scale(x, seasonuse, daytype, hour, m, surface, allregions)=1e-2;
1560 intermediateBC2.scale(seasonuse, daytype, hour, m, surface, allregions)=1e-2;
1561 AHUenergybalfanret.scale(seasonuse, daytype, hour, allregions)=1e1;
1562 AHUenergybalcoilfansup.scale(seasonuse, daytype, hour, allregions)=1e2;
1563 AHUenergybalmixing.scale(seasonuse, daytype, hour, allregions)=1e3;
1564 AHUvapormassbalmixing.scale(seasonuse, daytype, hour, allregions)=1e1;
1565 );
1566
1567 If(ord(season)=3,
1568 Temperature.scale(x, seasonuse, daytype, hour, m, surface, allregions)=1e2;
1569 Temperatureprofile.scale(x, seasonuse, daytype, hour, m, surface, allregions)=1e-2;
1570 intermediateBC2.scale(seasonuse, daytype, hour, m, surface, allregions)=1e-2;
1571 AHUenergybalfanret.scale(seasonuse, daytype, hour, allregions)=1e1;
1572 AHUenergybalcoilfansup.scale(seasonuse, daytype, hour, allregions)=1e2;
1573 AHUenergybalmixing.scale(seasonuse, daytype, hour, allregions)=1e3;
1574 AHUvapormassbalmixing.scale(seasonuse, daytype, hour, allregions)=1e1;
1575 );
1576
1577
1578 Solve Qsystemcheck using NLP minimizing ctot;
1579
1580 *Specifying supply air properties here (we can specify these exogenously or fix other variables and let them be determined):
1581
1582 humidityratioinHVAC.fx(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)<0)=0.0050;
1583 humidityratioinHVAC.fx(seasonuse, daytype, hour, 'West')$(Qcooling.l(seasonuse, daytype, hour, 'West')<0)=0.0050;
1584 humidityratioinHVAC.fx(seasonuse, daytype, hour, 'Sout')$(Qcooling.l(seasonuse, daytype, hour, 'Sout')<0)=0.0075;
1585 humidityratioinHVAC.fx(seasonuse, daytype, hour, 'Cent')$(Qcooling.l(seasonuse, daytype, hour, 'Cent')<0)=0.0060;
1586 humidityratioinHVAC.fx(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)>0)=0.0105;
1587
1588 temperatureinHVAC.fx(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)<0)=Tindoor(hour, seasonuse, allregions)-273.15-12;
1589 temperatureinHVAC.fx(seasonuse, daytype, hour, 'Sout')$(Qcooling.l(seasonuse, daytype, hour, 'Sout')<0)=Tin>door(hour, seasonuse, 'Sout')-273.15-10;
1590 temperatureinHVAC.fx(seasonuse, daytype, hour, 'Cent')$(Qcooling.l(seasonuse, daytype, hour, 'Cent')<0)=Tin>door(hour, seasonuse, 'Cent')-273.15-12;
1591 temperatureinHVAC.fx(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)>0)=Tindoor(hour, seasonuse, allregions)-273.15+17;
1592
1593
1594 *COP is not the same for cooling and heating. Below, we define the cooling COP as a given
1595 *and the heating COP is related using the first law of thermodynamics:
1596 COP(seasonuse, daytype, hour, 'Cent')$(Qcooling.l(seasonuse, daytype, hour, allregions)<0)=7/3.412;
1597 COP(seasonuse, daytype, hour, 'West')$(Qcooling.l(seasonuse, daytype, hour, allregions)<0)=7.9/3.412;
1598 COP(seasonuse, daytype, hour, 'Sout')$(Qcooling.l(seasonuse, daytype, hour, allregions)<0)=6/3.412;
1599 COP(seasonuse, daytype, hour, 'East')$(Qcooling.l(seasonuse, daytype, hour, allregions)<0)=7.4/3.412;
1600 COP(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)>0)=COP(seasonuse, daytype, hour, allregions)+1;
1601
1602
1603 saveTemperatureinHVAC(seasonuse, daytype, hour, allregions)=temperatureinHVAC.l(seasonuse, daytype, hour, allregions);
1604 savehumidityratioinHVAC(seasonuse, daytype, hour, allregions)=humidityratioinHVAC.l(seasonuse, daytype, hour, allregions);
1605 savemassintakeAHU(seasonuse, daytype, hour, allregions)=massintakeAHU.l(seasonuse, daytype, hour, allregions);

```

```

s);
1606
1607
1608 Loop((intake, RHsup, Tsup),
1609 *To step forward the supply air properties and the quantity of mass intake:
1610 humidityratioinHVAC.fx(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)
ns)<0)=savehumidityratioinHVAC(seasonuse, daytype, hour, allregions)+0.00000*(ord(RHsup)-1);
1611 humidityratioinHVAC.fx(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)
ns)>0)=savehumidityratioinHVAC(seasonuse, daytype, hour, allregions)+0.00000*(ord(RHsup)-1);
1612
1613 temperatureinHVAC.fx(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)
)<0)=saveTemperatureinHVAC(seasonuse, daytype, hour, allregions)+(ord(Tsup)-1)/2;
1614 temperatureinHVAC.fx(seasonuse, daytype, hour, allregions)$(Qcooling.l(seasonuse, daytype, hour, allregions)
)>0)=saveTemperatureinHVAC(seasonuse, daytype, hour, allregions)-(ord(Tsup)-1)/2;
1615
1616 massintakeAHU.fx(seasonuse, daytype, hour, allregions)=savemassintakeAHU(seasonuse, daytype, hour, allregions)+(ord(intake)-1)/20;
1617
1618
1619 humidityratioinHVACrun(RHsup, seasonuse, daytype, hour, allregions)=humidityratioinHVAC.l(seasonuse, daytype, hour, allregions);
1620 TemperatureinHVACrun(Tsup, seasonuse, daytype, hour, allregions)=temperatureinHVAC.l(seasonuse, daytype, hour, allregions);
1621 MassintakeAHUrun(intake, seasonuse, daytype, hour, allregions)=massintakeAHU.l(seasonuse, daytype, hour, allregions);
1622
1623
1624 Solve Residential using NLP minimizing ctot;
1625
1626 *The total power consumption calculated takes off the power that would be
1627 *required for heating for houses that do not have electric space heaters(based
1628 *on saturation levels defined earlier):
1629 TotalPowerExcel(season, daytype, hour, allregions, 'b1')=
1630 (Totalpower.l(season, daytype, hour, allregions)
1631 - (TotalHVACpower.l(season, daytype, hour, allregions)*(1-spaceheatingsaturation(allregions)))$(Qcooling.l(season, daytype, hour, allregions)>0))*Numberofresidences(allregions);
1632
1633 *To report average monthly electricity consumption every season (currently not
1634 *accounting for HVAC power used for heating, assuming no heating power use):
1635 Monthlyelectricityconsumed(RHsup, Tsup, intake, season, allregions)=sum((daytype, hour), ( Totalpower.l(season, daytype, hour, allregions)
1636 - (TotalHVACpower.l(season, daytype, hour, allregions)*(1-spaceheatingsaturation(allregions)))$(Qcooling.l(season, daytype, hour, allregions)>0))
1637 )*Daysinseason(season)/Monthsinseason(season));
1638
1639 *To report the associated average monthly cost every season based on current
1640 *electricity tariffs:
1641 Monthlyelectricitycost(RHsup, Tsup, intake, season, allregions)=elecfixedariff
1642 +(electariff('b1')*monthlyelectricityconsumed(RHsup, Tsup, intake, season, allregions))$(upconsumptionlevel('b1')>=monthlyelectricityconsumed(RHsup, Tsup, intake, season, allregions))
1643 +sum(consbrack$(upconsumptionlevel(consbrack)<=monthlyelectricityconsumed(RHsup, Tsup, intake, season, allregions) and monthlyelectricityconsumed(RHsup, Tsup, intake, season, allregions)<=upconsumptionlevel(consbrack+1)), electariff(consbrack)*(monthlyelectricityconsumed(RHsup, Tsup, intake, season, allregions)-upconsumptionlevel(consbrack)))
1644 +sum(consbrack$(upconsumptionlevel(consbrack)<=monthlyelectricityconsumed(RHsup, Tsup, intake, season, allregions)), electariff(consbrack)*(upconsumptionlevel(consbrack)-upconsumptionlevel(consbrack-1))) ;
1645
1646 execute_unload 'PowerLoad.gdx' TotalPowerExcel;
1647 If( (ord(season)=card(season) and ord(allregions)=card(allregions)),
1648 execute 'gdxrw.exe PowerLoad.gdx o=PowerLoadVillasInsulate.xlsm Par=TotalPowerExcel rng=TotalPower!A2:Z1000';
1649 );
1650 *To reset values for next loop run:
1651 Totalpower.l(season, daytype, hour, allregions)=0;
1652 TotalHVACpower.l(season, daytype, hour, allregions)=0;
1653 Qcooling.l(season, daytype, hour, allregions)=0;
1654
1655 );
1656
1657 *To move the solve to the next season:
1658 seasonuse(season)=no;
1659 seasonuse(season+1)$(runallseasons=1)=yes;
1660

```

```

1661 );
1662
1663 *To move the solve to the next region:
1664 r_use(allregions)=no;
1665 r_use(allregions+1)$(runallregions=1)=yes;
1666
1667 );
1668 *****
1669 $INCLUDE Residential_Display_Variables.gms
1670 *****
1671 ;
1672 $ontext
1673 ****Exporting to Excel using GDX utilities:
1674 *Unloading to GDX file
1675 execute_unload 'results.gdx' Qsystem Texternalroof HVACpower distance
1676 Tempprofile directirradiance diffuseirradiance reflectedirradiance totalirrad
1677 Totalpower Tinternalroof Qcoil Tindoorrun humidityratioinHVACrun TemperatureinHVACrun
1678 Monthlyelectricityconsumed MassintakeAHUrun ;
1679
1680 *Writing parameters and variables to Excel files from GDX file
1681 *Results.xlsx; used to graphically present some of the main results
1682 execute 'gdxxrw.exe results.gdx o=Residential_Results.xlsx par=Qsystem rng=SysLoad!A1:AZ9999'
1683 execute 'gdxxrw.exe results.gdx o=Residential_Results.xlsx par=Texternalroof rng=RoofExtT!A1:AZ9999'
1684 execute 'gdxxrw.exe results.gdx o=Residential_Results.xlsx par=HVACpower rng=HVACpower!A1:AZ9999'
1685 execute 'gdxxrw.exe results.gdx o=Residential_Results.xlsx var=Totalpower rng=TotPower!A1:AZ9999'
1686 execute 'gdxxrw.exe results.gdx o=Residential_Results.xlsx par=Tinternalroof rng=RoofIntT!A1:AZ9999'
1687 execute 'gdxxrw.exe results.gdx o=Residential_Results.xlsx var=Qcoil rng=Qcoil!A1:AZ9999'
1688 execute 'gdxxrw.exe results.gdx o=Residential_Results.xlsx par=Tindoorrun rng=TindRun!A1:AZ9999';
1689
1690 *WallTemp.xlsx; used to graphically present the temperature profiles through walls and roof
1691 execute 'gdxxrw.exe results.gdx o=WallTemp.xlsx par=distance'
1692 execute 'gdxxrw.exe results.gdx o=WallTemp.xlsx par=Tempprofile rng=Sheet3!I1:L1251';
1693
1694 *Radiation.xlsx; used to graphically present solar irradiation profiles
1695 execute 'gdxxrw.exe results.gdx o=Radiation.xlsx par=directirradiance'
1696 execute 'gdxxrw.exe results.gdx o=Radiation.xlsx par=diffuseirradiance'
1697 execute 'gdxxrw.exe results.gdx o=Radiation.xlsx par=reflectedirradiance'
1698 execute 'gdxxrw.exe results.gdx o=Radiation.xlsx par=totalirrad';
1699
1700 *Supplyair.xlsx used to show results over a range of supply air properties:
1701 execute 'gdxxrw.exe results.gdx o=Supplyair.xlsx par=temperatureinHVACrun'
1702 execute 'gdxxrw.exe results.gdx o=Supplyair.xlsx par=humidityratioinHVACrun rng=Sheet3!G1:M251'
1703 execute 'gdxxrw.exe results.gdx o=Supplyair.xlsx par=massintakeAHUrun rng=Sheet3!O1:S251'
1704 execute 'gdxxrw.exe results.gdx o=Supplyair.xlsx par=Monthlyelectricityconsumed rng=Sheet3!U1:Z30';
1705 $offtext
1706
1707
1708
1709 execute_unload 'results.gdx' Regelecconsump nateleconsumplight NatelecconsumpAPP;
1710 execute 'gdxxrw.exe results.gdx o=regionalconsumpvillasInsulate.xlsx par=regelecconsump'
1711 execute 'gdxxrw.exe results.gdx o=regionalconsumpvillasInsulate.xlsx par=nateleconsumpLight rng=Sheet3!K1:Q20'
1712 execute 'gdxxrw.exe results.gdx o=regionalconsumpvillasInsulate.xlsx par=NateleconsumpAPP rng=Sheet3!R1:Z20';
1713

```