

			Laboratory		
			Nano 1	Nano 2	Nano 3
Measures					
Technical	Ventilation	Chemistry lab type (renewal without recycling 5-10 X/h)	x	x	x
		With at least sealed F7 filter (maintenance!) for exiting air			x
		Low pressure in the room	x	x	> 20 mPa
		Capture at source		x	x
	Floor	Flooring	Tiling or linoleum		Resin
	Manipulation under fume hood	Optional	x (1)		
		Compulsory		x	x
	Access restriction	Restricted (magnetic card access control system)		x	x
		Regular lab access control (laboratory key)	x		
		Evidence about exposed people + board to record presence			x
	SAS entrance and exit	Double SAS (if > 100 g ultrafine particles)			x
		Simple SAS (is < 100 g ultrafine particles)		Light SAS	x
		Safety shower			x
	Use of vacuum cleaners	Asbestos type	x	x	x
		Housekeeping type	Forbidden		